



valveIT®

Via Caduti di Reggio Emilia 27, 40033
Casalecchio di Reno (BO)
www.valveit.com
info@valveit.com



SRI LANKA

APPROVAL COLLECTION

2016-2024

PRO AT FLUID CONTROL



MATERIAL APPLICATION

Project: Havelock City Project - Phase IV **Submittal No:** ICC/HCP-IV/MA/FIRE/SF/037

Description of Material

Material: OS & Y Resilient Seated Gate Valve
Brand /Make: Valve IT
Country of Manufacture : Italy
Model No: VIT-GTR-300

Local Supply
Imported From

Italy

Reference Contract Drawing

No./Detail/Section

P-H-42-01

Reference Contract Specification / Document

ECAD spec section 7, Pipes & Fittings

Applicable Standards as per Drawings / Document

N/A

Special Details / Descriptions (if any)

300PSI

Name of Standards

UL Listed / FM Approved

Additional Description & Material Description

Body : Ductile Iron
 Stem : Stainless Steel
 Valve Sizes : 200, 150 & 100mm

Attachments

Technical Data Sheet of Manufacturer

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

2018: 02: 06

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

ICC - Havelock City P-V

08 MAR 2018

Received

EMPLOYER'S PM

Approved

Not Approved

Remarks * All valves should come from Italy by direct LC.
 * Please provide proper reference list for all valves

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

07.03.2018

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV

Submittal No: ICC/HCP-IV/MA/FIRE/SF/038

Description of Material

Material: Ball Cock Valve

Brand /Make: Valve IT

Country of Manufacture : Italy

Model No: VIT-25-BLBZ

Local Supply

Imported From

Italy

**Reference Contract Drawing
No./Detail/Section**

P-G-31-03A

**Reference Contract Specification
/ Document**

ECADI spec section 7, Pipes & Fittings

**Applicable Standards as per
Drawings / Document**

Not mention in the spec

**Special Details / Descriptions (if
any)**

Body : Bronze
Ball : DZR Brass

Name of Standards

**Additional Description & Material
Description**

Valve Sizes : 15, 20 & 25mm
Pressure Rating : PN25



Attachments

**Technical Data Sheet of
Manufacturer**

V

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

[Signature] 2018.02.06

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

[Signature] 06.22.2018

EMPLOYER'S PM

Approved **Not Approved**.....

ICC - Havelock City PIV

08 MAR 2018

Received

07.03.2018

Date

Remarks

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

[Signature]

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV

Submittal No: ICC/HCP-IV/MA/FIRE/SF/039

Description of Material

Material: Check Valve

Brand /Make: Valve IT

Country of Manufacture : Italy

Model No: VIT-SCF-300

Local Supply

Imported From

Italy

Reference Contract Drawing

No./Detail/Section

P-H-42-01

Reference Contract Specification / Document

ECADI spec section 7, Pipes & Fittings

Applicable Standards as per Drawings / Document

Not mention in the spec

Special Details / Descriptions (if any)

Body : Ductile Iron
Pressure Rating : 300PSI

Name of Standards

UL Listed / FM Approved

Additional Description & Material Description

Valve Sizes : 150, 100, 80 & 50mm

Attachments

Technical Data Sheet of Manufacturer

✓

Test Certification

N/A

Other

Subcontractor

Requested By. (Name) CONFIDENTIAL

Signature / Date

[Signature] 2018.02.26

ICC

Requested By. (Name) CONFIDENTIAL

Signature / Date

[Signature] 20/2/2018

EMPLOYER'S PM

Approved ✓

Not Approved

Remarks

Name of Employer's PM

Signature of Employer's PM

Date



07-03-2018

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV

Submission No: ICC/HCP-IV/MA/FIRE/SF/040

Description of Material

Material: SS Flexible Connection

Brand /Make: Valve IT

Country of Manufacture : Italy

Model No: VIT-16-FBS

Local Supply

Imported From:

Italy

**Reference Contract Drawing
No./Detail/Section**

P-H-42-01

**Reference Contract Specification
/ Document**

Not mention in the spec

**Applicable Standards as per
Drawings / Document**

Not mention in the spec

**Special Details / Descriptions (if
any)**

Bellow : Stainless Steel
Flange: Carbon Stainless steel

Name of Standards

**Additional Description & Material
Description**

Size : 65, 80, 100 & 150mm



Attachments

**Technical Data Sheet of
Manufacturer**

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date



2018.02.06

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

06/02/2018

EMPLOYER'S PM

Approved ✓

Not Approved

Remarks



CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

07.03.2018

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV **Submittal No:** ICC/HCP-IV/M-VFIRE/SF/041

Description of Material

Material: Pressure Reducing Valve
Brand /Make: Valve IT
Country of Manufacture : Italy
Model No: VIT-25-PRB

**Local Supply
Imported From**

Italy

**Reference Contract Drawing
No./Detail/Section**

P-G-31-03A

**Reference Contract Specification
/ Document**

ECADI spec section 7, Pipes & Fittings

**Applicable Standards as per
Drawings / Document**

Not mention in the spec

**Special Details / Descriptions (if
any)**

Maximum inlet Pressure : 25 bar
 Downstream Pressure range : 1 - 6 bar
 Maximum Temperature : 100° C

Name of Standards

**Additional Description & Material
Description**

Size : 1/2" - 4"



Attachments

**Technical Data Sheet of
Manufacturer**

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL



Signature / Date 2018.02.06

Requested By. (Name)

ICC

CONFIDENTIAL

Signature / Date 06/02/2018

Requested By. (Name)

ICC - Havelock City P-IV

EMPLOYER'S PM

Approved ✓

Not Approved

08 MAR 2018

Remarks

Received

CONFIDENTIAL

Signature

07.03.2018

Name of Employer's PM

Signature of Employer's PM

Date

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV

Submittal No: ICC/HCP-IV/MA/FISE/SF/043

Description of Material

Material: Air Release Valve

Brand /Make: Valve IT

Country of Manufacture : Italy

Model No: VIT-10-ABV

Local Supply
Imported From

Italy

Reference Contract Drawing
No./Detail/Section

P-G-22-01

P-H-22-01

Reference Contract Specification
Document

ECADI spec section 7, Pipes & Fittings

Applicable Standards as per
Drawings / Document

Not mention in the spec

Special Details / Descriptions (if
any)

Size : 1/2" - 3/4"

Name of Standards

Additional Description & Material
Description

Body : Brass
Cap : Brass



Attachments

Technical Data Sheet of
Manufacturer

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

[Signature] 2018.02.06



ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

[Signature] 06/02/2018

ICC - Havelock City/PM

EMPLOYER'S PM

Approved ✓

Not Approved

08 MAR 2018

Remarks

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

[Signature]

07.03.2018



MATERIAL APPLICATION

Project: Havelock City Project - Phase IV **Submittal No:** ICC/HCP-IV/MA/FIRE/SF/044

Description of Material

Material: Pressure Release Valve
Brand / Make: Valve IT
Country of Manufacture: Italy
Model No: VIT-25-VRCA

Local Supply
Imported From

Italy

Reference Contract Drawing
No./Detail/Section

P-H-12-01

Reference Contract Specification
/ Document

ECAD per section 7, Pipes & Fittings

Applicable Standards as per
Drawings / Document

Not mention in the spec

Special Details / Descriptions (if
any)

Body : Ductile cast iron
 Size : 50, 80 & 100mm

Name of Standards

Additional Description & Material
Description

Pressure Rating: PN 25



Attachments

Technical Data Sheet of
Manufacturer

v

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

[Signature] 2018.02.06




ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

[Signature] 07.02.2018



EMPLOYER'S PM

Approved

Not Approved

Remarks

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

[Signature]

07.03.2018

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV **Submittal No:** ICC/HCP-IV/MA/FIRE/SF/045

Description of Material

Material: Pressure Gauge

Brand / Make: Valve IT

Country of Manufacture: Italy

Model No: V-T-25-PSG

Local Supply
Imported From

Italy

Reference Contract Drawing

No./Detail/Section

P-H-42-01

Reference Contract Specification

/ Document

Not mention in the spec

Applicable Standards as per

Drawings / Document

Not mention in the spec

Special Details / Descriptions (if any)

Case size: 100mm
Pressure Range : 0-25 bar

Name of Standards

Additional Description & Material Description

Case : Steel case with Black muffing

Attachments

Technical Data Sheet of Manufacturer

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

EMPLOYER'S PM

Approved

Not Approved

Remarks

Post certificate required?

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

07.03.2018



ICC - Havelock City P-IV

08 MAR 2018

Received

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV **Submittal No:** ICC/HCP-IV/MA/FIRE/SF/046

Description of Material

Material: 200mm Foot Valve

Brand /Make: Valve IT

Country of Manufacture : Italy

Model No:

Local Supply
Imported From

Italy

Reference Contract Drawing
No./Detail/Section

P-H-42-01

Reference Contract Specification
/ Document

ECADI spec section 7, Pipes & Fittings

Applicable Standards as per
Drawings / Document

Not mention in the spec

Special Details / Descriptions (if
any)

Body & Disc : Ductile Iron, PN16

Name of Standards

Additional Description & Material
Description

Shaft : X20Cr13

Seals : EPDM

Spring & Strainer : Stainless Steel

Attachments

Technical Data Sheet of
Manufacturer

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

ICC - Havelock City P-IV

EMPLOYER'S PM

Approved ☒ **Not Approved** ☐

06 APR 2018

Remarks

Received

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

04.04.2018

MATERIAL APPLICATION

Project: Havelock City Project - Phase IV

Submittal No: ICC/HCP-IV/MA/FIRE/SF/047

Description of Material

Material: Y Strainer

Brand /Make: Valve IT

Country of Manufacture: Italy

Model No: VIT-Y F-175

Local Supply
Imported From

Italy

Reference Contract Drawing
No./Detail/Section

P-H-42-01

Reference Contract Specification
/ Document

LOA-01 spec section 7 Pipes & Fittings

Applicable Standards as per
Drawings / Document

Not mention in the spec

Special Details / Descriptions (if
any)

Body : Cast iron
Screen : Stainless Steel

Name of Standards

Additional Description & Material
Description

Size : 65, 80, 100, 150 & 200mm

Attachments

Technical Data Sheet of
Manufacturer

V

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date



2018.02.06

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

06.02.2018

EMPLOYER'S PM

Approved

Not Approved

Remarks

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

07.03.2018



MATERIAL APPLICATION

Project: Havelock City Project - Phase IV **Submission No:** ICC/HCP-IV/MA/FIRE/SF/048

Description of Material

Material: Butterfly Valve with Temper Switch
Brand / Make: Valve It
Country of Manufacture: Italy
Model No: VIT-BFG-300

Local Supply
Imported From

Italy

Reference Contract Drawing No./Detail/Section

P-G-31-03A

Reference Contract Specification / Document

ECADI spec section 7, Pipes & Fittings

Applicable Standards as per Drawings / Document

Not mention in the spec

Special Details / Descriptions (if any)

Body : Ductile Iron

Name of Standards

UL Listed / FM Approved

Additional Description & Material Description

Size : 65, 80, 100 & 150mm

Attachments

Technical Data Sheet of Manufacturer

V

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date

ICC

CONFIDENTIAL

Requested By (Name)

Signature / Date

EMPLOYER'S PM

Approved ☒

Not Approved ☐

08 MAR 2018

Remarks

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

07.03.2018



MATERIAL APPLICATION

Project: Havelock City Project - Phase IV

Submittal No: ICC/HCP-IV/MA/FIRE/SF/049

Description of Material

Material: Pressure Switch

Brand /Make: Valve IT

Country of Manufacture : Italy

Model No: ELT-36

**Local Supply
Imported From**

Italy

Reference Contract Drawing

No./Detail/Section

P-H-42-01

**Reference Contract Specification
/ Document**

ECADI spec section 7 Pipes & Fittings

**Applicable Standards as per
Drawings / Document**

Not mention in the spec

**Special Details / Descriptions (if
any)**

Pressure Sensitive Diaphragm Element : Chomed or Stainless Steel Bellow

Name of Standards

**Additional Description & Material
Description**

Cover : Thermoplastic polyamide
Range : 5/16 bar

Attachments

**Technical Data Sheet of
Manufacturer**

✓

Test Certification

N/A

Other

Subcontractor

CONFIDENTIAL

Requested By. (Name)

Signature / Date



2018.02.06

ICC

CONFIDENTIAL

Requested By. (Name)

Signature / Date

06/02/2018

ICC - Havelock City PM

EMPLOYER'S PM

Approved ✓

Not Approved

08 MAR 2018

Remarks

Received

CONFIDENTIAL

Name of Employer's PM

Signature of Employer's PM

Date

07.03.2018

ජාතික ජල සම්පාදන හා ජලාපවහන මණ්ඩලය
தேசிய நீர் வழங்கல் வடிகாலமைப்புச் சபை
National Water Supply & Drainage Board



තැ.ප.ප. }
Tel/Fax }

මගේ අංකය
எனது இல
My No.

} AGM(Doc)/PQ DI Valve/C 46

ඔබේ අංකය
உமது இல
Your No.

දිනය
திகதி
Date } 10.04.2023

ValveIT SRL
Via Caduit di Reggio Emilia, 25-27,
Casalecchio di Reno (Bologna),
40033, Italy.

Dear Sir/Madam,

Pre-Qualification of Manufacturers for Supply & Delivery of DI Valves

Document No.: PQ/DI VALVES/NWSDB/2011/01

Subject : Acknowledgement for the Submission

This refers to your pre-qualification application dated 28th March 2023 on the above and thankful for the submission.

Our pre-qualification process consists of detailed analysis of general, technical and financial aspects of the manufacturer including verification of certificates and signatures which will take approximately period of 02 months.

We will contact you if any further clarification is needed.

Your corporation on submitting all the requested details is highly appreciated.

Yours faithfully,

National Water Supply & Drainage Board

**Assistant General Manager
(Tenders & Contracts)**

CC : 1. M/s. Global Drive Industrial Solutions (Pvt) Ltd - for your action please