



valveIT®

Via Caduti di Reggio Emilia 27, 40033
Casalecchio di Reno (BO)
www.valveit.com
info@valveit.com



UAE

APPROVAL COLLECTION


2016-2024



PRO AT FLUID CONTROL





CERTIFICATE OF MATERIAL APPROVAL - MEP-HVAC				
Name of Project	Proposed Construction of 2B+G+19 building on Plot No. 673-1242 at Al Barsha 3rd, Dubai, U.A.E			
Name of Main Contractor	M/s GULF ASIA CONTRACTING CO. LLC		Ref. No.:	GAC/GPS/CHM/MEP/CHM/HVAC/5180 RAC/286/1814/PG/7941/ME/CHM/053 REV-00
Name of MEP Contractor	M/s CHM STAR ELECTROMECHANIC LLC		Date Submitted	22.03.2018
Materials	As Specified		Proposed Material	
HVAC MATERIALS	B.O.Q Ref. No.		Description as per BOQ	DESCRIPTION
	Dwg. Ref. No.			AIR SEPERATOR
	Specs. Ref. No.			
Location/Use	HVAC WORKS			
Name of Manufacturer	AIR SEPERATOR			
Name of Local Agent	VALVELT			
Remarks	03 HARD COPIES			
Submitted by	Consultant's Approval		Client's Approval	
M/s Gulf Asia Contracting	<i>Air Separator from VALVELT - ITALY is approved subject to compliance of following:-</i> <i>1) Flow through Air Separator shall not be less than 180 l/s. Proposed selection is not acceptable.</i> <i>2) PN 16 pressure rating</i> <i>3) Delivery to match with project schedule.</i> <i>4) 5 years warranty for the system to be given.</i>		 	

FOR CHAWLA ARCHITECTURAL AND CONSULTING ENGINEERS

شركة شاولا الهندسة المعمارية والاسطوانات
 CHAWLA ARCHITECTURAL &
 CONSULTING ENGINEERS
 P.O. Box 281 Tel: 3493435
 Dubai - U.A.E Fax: 3492030

Associates:

ARC LINE DÉCOR, Post Box: 52675, Dubai (U.A.E.) Tel: 04 3496750 Fax: 3444306 E MAIL: arcinedecor@hotmail.com

AL MADAR ENG. CONSULTANTS, P.O. Box: 28732, Sharjah (U.A.E.) Tel: 06 5739959 Fax: 06 5739059 email: almadar1@emirates.net.ae

 مؤسسة الصرف الصحي Wastewater Agency	STANDARD OPERATING FORM (SOF-01)	 Stantec 
	MATERIAL SUBMITTAL FORM	

Request for Approval of Material ☐ Civil ☒ Mech. ☐ E & IC

CONTRACTOR USE

Contract No.	AF-IW-0115-01-00	Material Description:	Manual and Auto Valves
Contract Title	Construction of Inlet Works for Al Filayah Sewage Treatment Plant		
Contractor	Metito Overseas Limited	Manufacturer Name:	VALVEIT
Contractor's Submittal Reference No.	120191000-04-204	Supplier Name:	VALVEIT
		Country of Origin:	Italy
Revision	A	Model/Type:	Ball, Butterfly, Diaphragm, Gate, Sluice Gate, Knife Gate, Solenoid, Check
Date	24.10.2019	Specification Ref.	General Specification of Mechanical Works SECTION 15020
Proposed Area of Application	Sewerage Works	BOQ Ref.	Bill no. 4, page no. B/4/23,25,28,29,31
Quantity	45 nos.		

Attachment (in separators)					Contractor's Certification: Date: 24-10-2019 Contractor's Signature and Stamp:  
A	Compliance/Deviation form attached	☒ Yes	☐ No	☐ N/A	
B	Relevant Catalogue/Brochure/Drawing (marked)	☒ Yes	☐ No	☐ N/A	
C	C.1- Manufacturer Quality Certificate (ISO or Other)	☒ Yes	☐ No	☐ N/A	
	C.2- Copy of Relevant International Certificates	☒ Yes	☐ No	☐ N/A	
D	D.1- Copy of Related Page of B.O.Q (marked)	☐ Yes	☐ No	☒ N/A	
	D.2- Copy of Related Contract Specification	☒ Yes	☐ No	☐ N/A	
	D.3- Copy of approved shop Drawing/Sketch	☐ Yes	☐ No	☒ N/A	
E	Relevant ITP attached	☒ Yes	☐ No	☐ N/A	
F	F.1- Safety Data Sheets Attached	☐ Yes	☐ No	☒ N/A	
	F.2- Material Data Sheets Attached	☐ Yes	☐ No	☒ N/A	
	F.3- Technical Data Sheets Attached	☒ Yes	☐ No	☐ N/A	
G	Applicator's Method Statement Attached	☐ Yes	☐ No	☒ N/A	
H	H.1- Samples Provided	☒ Yes	☐ No	☐ N/A	
	H.2- Results Provided	☐ Yes	☐ No	☒ N/A	
I	Other Enclosure (If any)	☒ Yes	☐ No	☐ N/A	

CONSULTANT USE

 P.O. Box: 11991, Abu Dhabi, U.A.E. CONSTRUCTION DIVISION	Recommendation:	Insert the action Code
		[A] for Approved, subject to contract requirements
		[B] for Approved as noted, resubmission not required
		[C] for Disapproved pending corrections, resubmission required
		[D] for Rejected
	[E] for Returned as incomplete without complete review	

Consultant: (Name, sign, date & stamp)  06/11/19	Comments: => Please Refer to the attached comments sheet => Please Refer to the comments highlighted on the attached Submittal.
RAKWA: (Name, sign, date and stamp)	

Note: The above comments and / or approvals do not relieve the contractor from his obligation under the Contract to ensure conformance to the specification. Any specification deviation found subsequent to approval shall be corrected by Contractor to the satisfaction of RAKWA.

This form shall remain attached to the submittal throughout its review and shall be kept as permanent record.

THIS FORM IS REFERED IN PROJECTS EXECUTION PROCEDURE OF RAKWA's MANAGEMENT SYSTEM

 RAKWA	 MWH	 VEOLIA
Project: AI FILAYAH SEWAGE TREATMENT PLANT UPGRADE		
Technical Submittal		TS Ref. No. 415026201-VWSE-KBR-082
		Rev. No. 1

Originator of the Submittal: **CONFIDENTIAL** Date: **07/12/2016**

Originator Signature: _____ Req'd. By: _____

Subject of Submittal: **Valves Technical Submittal**

☐ Pre-Qualification of Subcontractor ☐ Method Statement ☐ Guarantee ☐ Certificate ☐ Test Results ☒ Others

Attachments: 1. 415026201-MSP-011 Rev B - Technical Submittal Valves
2. Veolia reply to comments dated 07-12-2016.

Contractor Name / Signature: **VWS Emirates (LLC)** Date: **07/12/2016**

Consultant / Engineer / Received: _____ Date: **07/12/2016**

The Engineer's Comments:

Please note that This Approval does not Relieve you from any of your contractual obligations.

RE (MWH)

- ☒ A - Approved
☐ B - Approved Subject to Conditions
☐ C - Revise and Resubmit
☐ D - Incomplete Submission, Rejected

Signature:  Date: **28/12/2016**



MATERIAL SUBMITTAL FORM

MOHAMMED BIN RASHID AL MAKTOUM CITY

DISTRICT ONE - PH3A.1 - (BP2 & BP3)

PIC

Submittal Title:	MATERIAL SUBMITTAL FOR PLUMBING VALVES	Date	10-May-2022
Submittal No.:	DI-PH3A.1-BP2-BP3-RES-PIC-AE7-MTS-PL-0028	Revision	00

We are sending herewith under separate cover (please check one box):

☐ Architectural	☐ Structural	☐ Mechanical	☐ Electrical	☒ Plumbing
☐ Interior	☐ Landscape	☐ Infrastructure	☐ Other (specify)	

Ref. No.	Description	Copies	Remarks
DI-PH3A.1-BP2-BP3-RES-PIC-AE7-MTS-PL-0028	MATERIAL SUBMITTAL FOR PLUMBING VALVES	1+1	
Location of use: All Buildings			
☒ Manufacturer's Data	☐ Sample	☐ Guarantee	☒ Data Sheet
☒ Catalogue	☐ Reply to consultant comments	☒ Alternative	☐ Method statement
			☒ Test Certificate

Supplier/Manufacturer:	VALVEIT ITALY
Sub-Contractor Company:	Contractor Name: Parkway International Contracting LLC
Name and Signature:	Signature:
CONFIDENTIAL	CONFIDENTIAL
PROJECT MANAGER	PROJECT DIRECTOR
We certify that the documents / materials submitted herewith have been reviewed and found to be in full and complete conformance with the contract drawings and specifications except as otherwise stated.	

Consultant Remarks

- The proposed material has been reviewed & found acceptable.
- Qty & size shall be considered based on site Requirement & as indicated on approved drawings.

Approved	Approved as noted	Revise and Resubmit	Not Approved	Received By:
☐	☒	☐	☐	

Consultant Name / Signature / Date

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of The Contract. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades and performing his work in a safe and satisfactory manner.

Distribution:	☐ AE7 (Original)	☐ QS	☐ Contractor	☐ Others
---------------	---	-----------------------------	-------------------------------------	---------------------------------





Consultancy Services

SAMPLE TAG

MOHAMMED BIN RASHID AL MAKTOUM CITY

DISTRICT ONE -PH3A.1- (BP2 & BP3)

Logo



PIC

Manufacturer Submittal No.	DI-PH3A.1-BP2-BP3-RES-PIC-AE7-MTS-PL-0028	Revision	00
Sample Submittal No.	DI-PH3A.1-BP2-BP3-RES-PIC-AE7-SAMP-EL-0028	Date	10-May-2022

We are sending under separate cover (please check one box):

☐ Structural	☐ Electrical	☐ Landscape	☒ Plumbing	☐ Other (Specify)
☐ Mechanical	☐ Infrastructure	☐ Interior	☐ Architectural	

Product Name:	Sample submittal for PLUMBING VALVES		
Where used:	For BP2 & BP3		
Spec. And/or Drawing Ref.			

Manufacturer Information:	VALVEIT ITALY		
Address:	ITALY	Product Source:	

Supplier Information:			
		Days required to deliver to site	
		Parkway International Contracting	
Manufacturer:		Contractor Name:	
Supplier:		Project Director:	
	VALVEIT ITALY		
Name and Signature:		Signature:	
CONFIDENTIAL			
Project Manager:			

Sample Description: PLUMBING VALVES

We certify that the documents submitted herewith have been reviewed in detail and are in strict conformance with the contract drawings and specifications except as otherwise stated.

Consultant Remarks			
REFER TO ATTACHED COMMENTS ae7 PIC. 17 MAY 2022 RECEIVED			
Approved	Approved as noted	Revise and Resubmit	Rejected
☐	☒	☐	☐
			Received By:

DDC-101026 M7-4794

The Employer:  SEVEN TIDES	Consultant:  Project: Anantara Sky Collection SUBJECT: MEP Works	Design & Built Turnkey Contractor: 																												
Material Submission																														
Originator of the Submittal: CONFIDENTIAL	Ref. No. MS-FC-09 Rev. No. 0 Date: 13-Mar-18 Requested Response Date: 18-Mar-18																													
Authorized Signature: 	Material Detail																													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">Item Description</td> <td>Chilled Water Valves</td> </tr> <tr> <td>Specs. / BOQ / Drwg. Reference</td> <td></td> </tr> <tr> <td>Material Specified</td> <td>As per approved vendor List</td> </tr> <tr> <td>Material Proposed</td> <td>as per specification</td> </tr> <tr> <td>Manufacturer / Local Supplier</td> <td>Valveit</td> </tr> <tr> <td>Reason for Alternative</td> <td></td> </tr> <tr> <td>Remarks</td> <td></td> </tr> </table>	Item Description	Chilled Water Valves	Specs. / BOQ / Drwg. Reference		Material Specified	As per approved vendor List	Material Proposed	as per specification	Manufacturer / Local Supplier	Valveit	Reason for Alternative		Remarks		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td colspan="2" style="text-align: center;"> List of Enclosure (Tick the Relative Box) </td> </tr> <tr> <td style="width: 50%;">☒ Vendor's Technical</td> <td></td> </tr> <tr> <td>☐ Compliance Statement</td> <td></td> </tr> <tr> <td>☐ Previous Test Results</td> <td></td> </tr> <tr> <td>☐ Copy of the Related Specs.</td> <td></td> </tr> <tr> <td>☐ Samples</td> <td></td> </tr> <tr> <td>☐ Others (Specify):</td> <td></td> </tr> </table>		List of Enclosure (Tick the Relative Box)		☒ Vendor's Technical		☐ Compliance Statement		☐ Previous Test Results		☐ Copy of the Related Specs.		☐ Samples		☐ Others (Specify):	
Item Description	Chilled Water Valves																													
Specs. / BOQ / Drwg. Reference																														
Material Specified	As per approved vendor List																													
Material Proposed	as per specification																													
Manufacturer / Local Supplier	Valveit																													
Reason for Alternative																														
Remarks																														
List of Enclosure (Tick the Relative Box)																														
☒ Vendor's Technical																														
☐ Compliance Statement																														
☐ Previous Test Results																														
☐ Copy of the Related Specs.																														
☐ Samples																														
☐ Others (Specify):																														
Contractor Statement: We certify that the material submitted herewith has been reviewed in detail and in compliance with the contract drawings and specifications except as otherwise stated hereabove.																														
Contractor Signature:		Date:																												
Received by Consultant / Resident Engineer :		Date:																												
Consultant / Resident Engineer's Comments:  																														
☐ A - Approved ☒ B - Approved As Noted ☐ C - Approved as Noted, Resubmit ☐ D - Not Approved, Resubmit																														
Consultant / RE's Signature:		Date:																												
Corrections or comments made in relation to submittals during this review does not relieve the contractor from compliance with the contract requirements and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents.																														

A2

SEVEN TIDES



SEVEN TIDES COMMENTS

REF. No.: ST-ADPJ-RAN-Comments-012

FOR CONSULTANT & CONTRACTOR DRAWING/SUBMITTAL/TRANSMITTAL FOR ANANTARA PROJECT

TO: M/s Fix Concrete

CONFIDENTIAL

CC: M/s PISI

CONFIDENTIAL

COMPANY: Fix Concrete

REFERENCE: MS-FC-09 dated 13th March 2018

ST DOC / ATT NO. 101036 / 4794

SUBJECT: Material Submission: Chilled Water Valves

SEVEN TIDES COMMENTS:

- 5 year warranty to provide.
- Country of origin to be provided
- Drain valves to provided with strainers
- Pressure rating PN-16 or above.
- All authorities approval to be obtained

Reviewed by:

Name:

CONFIDENTIAL

GM - Engineering

Signature:

For Information:

☐

Approved:

☐

Approved w/ Comments:

☒

Approved w/ Comments,
Resubmit:

☐

Not Approved, Resubmit:

☐

Not Approved, Rejected:

☐



ARTAR
ARTAR Engineering & Construction LLC



National Engineering Bureau
CONSTRUCTION & RECONSTRUCTION ENGINEERING COMPANY



CORRA
المركز الهندسي للإنشاء والتعمير
مجموعة شركات
CONSTRUCTION & RECONSTRUCTION ENGINEERING COMPANY
MEMBER OF CORRA GROUP

Project Name: G + 4P + 32F + HC, MADA Tower
On Plot No. 345-417 Burj Khalifa, Dubai

Project Code: 10100056

Material Submittal

Ref. No.: MTR/AC/PSEM-104
Date: 13.02.2018

Originator of Submittal:

Required By: **CONFIDENTIAL**

Material Division / Section:

List of Enclosures

(Tick the related Box)

Specs./BOQ/Drg. Ref.:

☒ Vendor's Technical Literature

Material Specified:

HVAC SERVICE PAGE NO 07 ITEM NO
2.17 - (VENDOR)

☐ Compliance Statement

Material Proposed:

ValveIT

☒ Test Results

Manufacturer / Local Supplier:

FluidTech FZE

☒ Copy of Related Specs.

Reason for Alternative:

☐ Samples

Material Description: AIR SEPARATORS

☒ List of Previous Projects done

☒ Others (Specify)

Contractor's PM: (Signature & Date)

Received by NEB: (Signature & Date)

CONFIDENTIAL

MADA TOWER
Prime Steel
Electrical and Mechanical Works LLC

14 FEB 2018

For:

Time: 6:15

Contractor's Statement: We certify that the material(s) submitted herewith has/have been reviewed in detail and in compliance with the Contract drawings and specifications except as otherwise stated here above.

Review Status

☐ A. Approved

☒ B. Approved As Noted

☐ C. Revise and Resubmit

☐ D. Not Approved

NEB Engineer's Representative Comments: - NO OBJECTION FOR VALVEIT (MADE IN ITALY)

- INSTALLATION SHOULD BE AS PER MANUFACTURING RECOMMENDATION.
- ORIGIN, GUARANTEE, CERTIFICATE TO BE SUBMIT AT DELIVERY
- SUBMIT TO PERFORMANCE AND FINAL TESTING & COMMISSIONING.
- MAINTENANCE CHECK LIST TO BE PROVIDED WITH O&M.

NEB Engineers Representative: (Signature & Date)

Received by Contractor: (Signature & Date)

ASR02

ENGINEERING CONSTRUCTION & RECONSTRUCTION COMPANY LLC
MEMBER OF CORRA GROUP

Client's / Representative Comments:

✓

28 FEB 2018
RECEIVED

RECEIVED




01 MAR 2018


Name


NEB NATIONAL ENGINEERING BUREAU
Signature & Date

The Engineer's Representative review, comments and approval to the submitted materials for general conformance with the design concept and specifications and shall not relieve the Contractor from responsibility for any deviations from, or errors or omissions in respect of the requirements of the Contract Documents, unless the Contractor has informed the Project Manager in writing of specific deviations and the Project Manager has given written approval thereto and no time and/or cost implication shall be granted due to the Engineer's P/M instruction.

PRIORITY ☐ URGENT ☐ TOP URGENT
SIGN.

Client 		Consultant 		Main Contractor 					
Project Name: DIYAFAH INTERNATIONAL SCHOOL PHASE 2		Project Code: 16-1656		Ref. No. : DIS/RAM/SI/MEP/032 Rev. 00					
Material Submittal				Date : 02-Jan-19					
Originator of Submittal :		Step International		Required By :					
Material Division / Section :		MEP Service		List of Enclosures (Tick the related Box) ☒ Vendor's Technical Literature ☒ Compliance Statement ☒ Test Results ☐ Copy of Related Specs. ☒ Samples ☒ List of Previous Projects done ☐ Others (Specify)					
Specs./BOQ/Drg. Ref. :		20 11 00 Valves							
Material Specified :		Hattersley / Crane / Toze / Kids							
Material Proposed :		ValveIT							
Manufacturer / Local Supplier :		ValveIT, SHARJAH							
Reason for Alternative :		Value Engineering							
Material Description :		Valves and Accessories for Chilled Water							
Contractor's PM: (Signature & Date)		Received by NEB: (Signature & Date)							
CONFIDENTIAL  									
Contractor's Statement: We certify that the material(s) submitted herewith has/have been reviewed in detail and in compliance with the Contract drawings and specifications except as otherwise stated herein.									
Review Status ☐ A. Approved ☒ B. Approved As Noted ☐ C. Revise and Resubmit ☐ D. Not Approved									
NEB Engineer's Representative Comments: → FOLLOW OUR COMMENTS ON THE ATTACHED SHEET, INCORPORATE ALL THE COMMENTS ACCORDINGLY.									
NEB Engineers Representative: (Signature & Date) 			Received by Contractor: (Signature & Date) 						
Client's/Employer's Representative Comments: 19/01/19									
<table border="1" style="width: 100%;"> <thead> <tr> <th style="width: 50%;">Name</th> <th style="width: 50%;">Signature/ Date</th> </tr> </thead> <tbody> <tr> <td colspan="2"> The Engineer's Representative review, comments and approval to the submitted material is for general conformance with the design concept and specifications and shall not relieve the Contractor from responsibility for any deviations from, or errors or omissions in respect of the requirements of the Contract Documents, unless the Contractor has informed the Project Manager in writing of specific deviations and the Project Manager has given written approval thereto and no time and/or cost implication shall be granted due to the Engineer's /PM instruction. </td> </tr> </tbody> </table>						Name	Signature/ Date	The Engineer's Representative review, comments and approval to the submitted material is for general conformance with the design concept and specifications and shall not relieve the Contractor from responsibility for any deviations from, or errors or omissions in respect of the requirements of the Contract Documents, unless the Contractor has informed the Project Manager in writing of specific deviations and the Project Manager has given written approval thereto and no time and/or cost implication shall be granted due to the Engineer's /PM instruction.	
Name	Signature/ Date								
The Engineer's Representative review, comments and approval to the submitted material is for general conformance with the design concept and specifications and shall not relieve the Contractor from responsibility for any deviations from, or errors or omissions in respect of the requirements of the Contract Documents, unless the Contractor has informed the Project Manager in writing of specific deviations and the Project Manager has given written approval thereto and no time and/or cost implication shall be granted due to the Engineer's /PM instruction.									





سلطة واحة دبي للسيليكون
Dubai Silicon Oasis Authority

Technical Submittal

Jan 6, 2020

EM-Construction & Projects
Construction Division



Design & ARchitecture bureau
Consulting Architects & Engineers



中建中東有限責任公司
CHINA STATE CONSTRUCTION ENGRG. CORP. (MIDDLE EAST) L.C.

Date: 30.12.2019

Ref. No.	CSCEC/MEP/TS/GN/282 Rev-0	Project No	P025/C
Plot No.	P-052/C-28-016	Project Name	DSOA SILICON PARK
Consultant	DESIGN & ARCHITECTURE BUREAU (DAR)	Contractor	CHINA STATE CONSTRUCTION ENGINEERING CORPORATION LLC
Submittal Type :	OPERATION & MAINTENANCE MANUAL FOR AIR SEPARATORS Rev-0		

Specification Ref.		File		
Your Ref.		File	<i>A/awp</i>	
Enclosure	☐	Architectural	☐	Interior Decoration
	☐	Structural	☐	Furnishing
	☒	MEP	☐	Equipment
	☐	Others.....		

1920212223242526272829

RECEIVED
10:35 PM
18 FEB 2020
CSSES

Description & Information:

Operation & Maintenance Manual for Air Separators (CSCEC -3 COPIES)

Authorized Representative	CONFIDENTIAL	Sign & Date	Up 30.12.2019
---------------------------	---------------------	-------------	---------------

Engineer Review

APP	AAN	NA
-----	-----	----

Comments	- in complete document s.c All document is missing). - The documents shall be submit as per Project documents & detail of system.		
Authorized Representative		Sign & Date	Feb 16

DSOA review	APP	AAN	NA
-------------	-----	-----	----

Comments	18 FEB 2020 9-84-1000 9-2017		
Authorized Representative		Sign & Date	117-2-2020

DSO/ EM-C&P/CONS/1026/R01

19/02/20


لمزيد من المعلومات: هاتف: +971 4 501 5000 / +971 4 501 5264 / فاكس: +971 4 501 5277 الموقع الإلكتروني: www.dso.ae البريد الإلكتروني: c&p@dso.ae

For more information: Call +9714 5015000 / 5015264, Fax: +9714 5015277 www.dso.ae Email: c&p@dso.ae



DSOA - P052 - SILICON PARK

Plot No. 28-016, Nadd Hessa, Dubai, U.A.E



PROJECT 	MEPC 	MC 	NSC 	Description: Material Submission Form
				FORM NO. EAM-NSC-F-04

Proposed Material :

Strainer

Date of submission: 18-6-2020 Submission Ref:ADD-S&W-PHE-MAR-0014 Rev. No. R2

Material description:

Sr No.	Description	Technical Specification
1	Manufacturer	Valveit
2	Item	Strainer
3	Application	Domestic Water Supply
4	Model	VIT-16-YDS & VIT-20-YSBZ
5	Location	Tower 1 / Tower 2
6	Y-Strainer Size	2" , 3" , 4" , 6"

Manufacturer: Valveit

Country Of Origin: Italy

Supplier Address: Fluid Tech FZE,UAE

Location of Use: Tower 1 / Tower 2

Spec. ref. / Drg. Ref. : Specification reference as per plumbing, sanitary,gas and swimming pool system page no 31

B.O.Q. ref.: 4.3d.E.5 - 2D.46

Date Material required on site:

NSC's comments (If any):

Attachments/enclosures:

☒ Catalogues ☐ Drawings ☐ Samples ☐ Others

NSC: Vikash Bhagat

SPLL:

(PREPARED BY)

Project Manager

MEP Engineer / Manager

Technical Manager

AGM

NSC Comments,

01). Maximum Perforation Size Dia. 80mm and above Valves should be 1.0mm and below sizes should be 0.8mm.
02). List of Valves with sizes and further details of Screen with Valve sizes should be provided.
03). Complete detail catalog should be provided.

Engineers / Consultant's comments:

Status:

☐ Approved ☒ Approved with comments ☐ Not Approved revise and resubmit ☐ Rejected as per comments

Signature

Name: **CONFIDENTIAL**

Date: 22/06/2020

Project Manager

Shapoorji Pallonji Lanka (Pvt) Ltd.
No 602 & 606, Galle Road, Colombo 03, Sri Lanka

RECEIVED

Received by

Date: 22 June 2020 Time: 4:00 PM

PROJECT 	MEPC 	MC 	NSC 	Description: Material Submission Form
				FORM NO. EAM-NSC-F-04

Proposed Material :

Strainer

Date of submission: 26-11-2019
Submission Ref:ADD-S&W-PHE-MAR-0014 Rev. No. R1
Material description:

Sr No.	Description	Technical Specification
1	Manufacturer	Valveit
2	Item	Strainer
3	Application	Domestic Water Supply
4	Model	VIT-16-YDS & VIT-20-YSBZ
5	Location	Tower 1 / Tower 2
6	Y-Strainer Size	2" , 3" , 4" , 6"

Manufacturer: Valveit

Country Of Origin: Italy

Supplier Address: Fluid Tech FZE,UAE

Location of Use: Tower 1 / Tower 2

Spec. ref. / Drg. Ref. : Specification reference as per plumbing, sanitary,gas and swimming pool system page no 31

B.O.Q. ref.: 4.3d.E.5 - 2D.46

Date Material required on site:

NSC's comments (If any):

NJC Comments;

01. Further details of Screen should be provided with each sizes. (Hole dia, no of holes cm2, distance between 2nos of holes, open area %)

Attachments/enclosures:



Catalogues



Drawings



Samples



Others

NSC: Vikash Bhagat SPL:

(PREPARED BY)




Project Manager



MEP Engineer / Manager



Technical Manager



AGM

Engineers / Consultant's comments:

Status:



Approved



Approved with comments




Not Approved revise and resubmit



Rejected as per comments

Signature



Name:

CONFIDENTIAL

Date:

27/11/2019

Project Manager

Date

PROJECT 606 THE ADDRESS	MEPC n=j CONSULTANTS	MC Shreeji Patil	NSC Shreeji Patil	Description: Material Submission Form
				FORM NO. EAM-NSC-F-04

Proposed Material :
Strainer

Date of submission: 24-10-2019

Submission Ref: ADD-S&W-PHE-MAR-0014 **Rev. No.** R0

Material description:

Sr No.	Description	Technical Specification
1	Manufacturer	Valveit
2	Item	Strainer
3	Application	Domestic Water Supply
4	Model	VIT-16-YDS & VIT-20-YSBZ
5	Location	Tower 1 / Tower 2
6	Y-Strainer Size	2" , 3" , 4" , 6"

Manufacturer: Valveit

Country Of Origin: Italy

Supplier Address: Fluid Tech FZE,UAE

Location of Use: Tower 1 / Tower 2

Spec. ref. / Drg. Ref. : Specification reference as per plumbing, sanitary, gas and swimming pool system page no 31

B.O.Q. ref.: 4.3d.E.5 - 2D.46

NJC Comments

Date Material required on site:

NSC's comments (If any):

01. Screen should be SS316 and Screen Details should be provided(hole size with each Dia.)
02. Nut & Bolt Should be hot dipped Galvanized or SS 304.

Attachments/enclosures:

☒ Catalogues ☐ Drawings ☐ Samples ☐ Others

NSC: Vikash Bhagat SPILL:

(PREPARED BY)

Vikash

[Signature]

[Signature]

[Signature]

Project Manager

MEP Engineer / Manager

Technical Manager

AGM

Engineers / Consultant's comments:

Status:

☐ Approve ☒ Approved with comments ☐ Not Approved revise and resubmit ☐ Rejected as per comments

Signature


[Signature]

Name: **CONFIDENTIAL**

Date: 07/11/2019

Project Manager

Date



MATERIAL APPROVAL SUBMITTAL

Project:	A4/A1b - IL PRIMO By EMAAR	Employer:	EMAAR
Engineer:	WSP	Architect:	WSP
Cost Consultant:	AECOM	Contractor:	TAV Construction

Discipline:	Civil C	Strucs S	Mech M	Elec E	Arch A	(Specify)	Submittal Ref:	A04-TAV-WSP-MD-P-0155	REV. 05
Location:							Date:	30-Jan-2019	
List of Submitted Items:									
Item	Description					No of Copies	Remarks		
01	Material and Sample Submittal for Plumbing Duty Valves (Gate Valve, Butterfly Valve, Regulating Valve, Non – Return Valve, Strainers and Air Vent)					01	Physical Sample provided		
Ref. Spec (s):						Ref. Drwg (s):			

Compliance Statement:

The Contractor hereby confirms that the submitted items have been reviewed in detail and are correct and in strict conformance with the Contract Documents. (compliance statement attached)

Initiator	QA/QC Manager	Project Manager
	CONFIDENTIAL	CONFIDENTIAL
Name, Signature & Date	Name, Signature & Date	Name, Signature & Date

REVIEWER'S COMMENTS

WSP (PLUMBING) A ☐ B ☒ C ☐ D ☐

ARCHITECTS A ☐ B ☐ C ☐ D ☐

Mechanical: B, No objection subject to comments:

Refer to WSP comments on attached supplier response sheets in page 6, 7, & 8.

CONFIDENTIAL 21.02.2019

Name, Signature and date

Comments Sheet Attached? Yes ☐ No ☐

Name, Signature and date

Comments Sheet Attached? Yes ☐ No ☐

ENGINEER/ EMPLOYER'S REPRESENTATIVE A ☐ B ☐ C ☐ D ☐

Name & Signature:

Date:

Note: The Engineer's / Consultants approval shall not in any way relieve the Contractor of his obligation under the Contract. The Contractor shall be solely responsible for the soundness and the correctness of the submitted Materials and Documents as per the required Contract Conditions and Contract Clauses

PROJECT: ACT ONE & ACT TWO TOWERS



CLIENT :	EMAAR DEVELOPMENT PJSC
PROJECT MANAGER:	MACE INTERNATIONAL
SUPERVISING CONSULTANT:	ARCHGROUP
MAIN CONTRACTOR:	CHINA STATE CONSTRUCTION ENG.CORP. (MIDDLE EAST) (L.L.C.)
SUB CONTRACTOR:	RELIANCE CONTRACTING COMPANY



MATERIAL APPROVAL SHEET (MAS)

Planned Submission Date : 07-JANUARY-2018	Actual Submission Date: 11-December-2018
Submittal No. C1-C2-RCC-P-MAS-018	Rev. 01 Date: 11-December-2018
Previous Submittal Ref No. N/A	Rev. 00 Date: 19-November-2018
Originator : RELIANCE CONTRACTING COMPANY	Sign of Originator :

Material Detail

List of Enclosure

Item Description	PLUMBING VALVES	(Tick the Related Box)
Specs. Reference	Volume -III-B (book 5 of 18) MEP works specifications Mechanical-R1 section 3&6.	☒ Vendor's Technical Literature
BOQ Reference	N/A	☒ Compliance Statement
Drg. Reference	N/A	☐ Previous Test Results
Material Specified/ Country of Origin	PLUMBING- General Requirements for Valves & Ancillaries N/A	☒ Copy of the Related Specs.
Material Proposed/ Country of Origin	Valve IT for Valves Plumbing Italy	☒ List of Previous Projects Done
Manufacturer/ Local Supplier	ValveIT/FLUIDTECH FZE (FULLY OWNED SUBSIDIARY OF VALVEIT)	☒ Samples
Reason for Alternative	N/A	☐ Guarantee
GBR	N/A	☐ Green Building Compliance
Remarks/Location	Valve for Water Supply	☒ Others (specify) Certificate of Origin,

Main Contractor's Statement

We certify that the material submitted herewith has been reviewed in detail and is in full compliance with the contract drawings, design requirement and specifications except as otherwise stated here above. The material submission shall be to the satisfaction of the supervising consultant that the material offered is equal or superior to and fully complies with the material specified in the contract's technical specification.

Main Contractor Signature :

Date : 13/12/18

Sub-Consultant- _____ Comments :

ARCHGROUP Comments :

- Minimum working pressure of valves shall be as specified.
- Refer comments on 'compliance to specification page' and schedule of proposed valves.
- Refer Emaar comments on attached sheet for strict compliance.

STATUS of Approval :

Status A	Status B	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator	MEP Manager 	Resident Engineer 
---------------------	---	---

SUPERVISING CONSULTANT PROJECT DIRECTOR :

Employer / PMO's Consent Required (Review by exception only): [] Yes [] No

Emaar MEP : Material Recommended ☐ / Rejected ☐

Emaar Security / IT: Material Recommended ☐ / Rejected ☐

Other Emaar Departments: Material Recommended ☐ / Rejected ☐

Emaar Development Director : Material Recommended ☐ / Rejected ☐

Project Manager: Material Recommended ☐ / Rejected ☐

Corrections or comments made relative to submittals during this review do not relieve the Contractor from compliance with the Contract requirement's, specifications and design concept. This check is for review of general project requirements only.

Main Contractor Received:
Date & Sign

PROJECT: Boulevard Point
PACKAGE: Main Works

MATERIAL SUBMITTAL

Contractor Name: Arabian Construction Company
Consultant Name: Dewan Al Emara Architects & Engineers

Package No: MW

DOCUMENT NO.	REV.	DESCRIPTION	DISCIPLINES	DOCUMENT TYPE
BP-MW-ASU-SM-PL-00013	R01	Sample for Plumbing Valves - 2. Nos Samples	Plumbing	Sample

Drawing / Drawing Number:	_____	List of Enclosure
Spec. / BOQ/ Dwg. Reference :	Vol. 3 Part-E Sec. 22 05 23	☐ Vendor's Technical Literature
Material Proposed :	Plumbing Valves	☐ Compliance Statement
Manufacturer / Local Supplier :	M/s. Value T-Italy / TRTS	☐ Previous Test Results
		☐ Copy of the Related Specs
		☒ Samples
		☐ List of Previous Projects Done
		☐ Others (Specify):
Signed:	_____	Date: _____

CONFIDENTIAL Project Manager

CONSULTANT COMMENTS:	STATUS
<i>Refer comments on attached sheet</i> <i>8/16/17</i>	☐ A - Approved
	☒ B - Approved As Noted
	☐ C - Revised and Resubmit

Signed: _____
CONFIDENTIAL - Chief Resident Engineer

Date: _____

PM COMMENTS: _____

Signed: _____

Date: _____

EMPLOYER COMMENTS: _____

Signed: _____

Date: _____

PROJECT: DOWNTOWN VIEWS II			
EMAAR	CLIENT :	EMAAR DEVELOPMENT PJSC	
	ENGINEER:	ARCHGROUP	
	MAIN CONTRACTOR:	CHINA STATE CONSTRUCTION ENGINEERING CORP. ME.LLC	
	SUB CONTRACTOR:		
MATERIAL APPROVAL SHEET (MAS)			
Planned Submission Date : February 15, 2019		Actual Submission Date: January 26, 2019	
Submittal No. DTVII-CSC-M-MAS-018		Rev. 02	Date: March 19, 2019
Sample Tag Ref No. DTVII-CSC-M-SAM-015		Rev. 02	Date: March 19, 2019
Previous Submittal Ref No. DTVII-CSC-M-MAS-018		Rev. 01	Date: March 3, 2019
Originator : China State Construction Engineering Corp.ME.L.L.C		Sign of Originator :	
[] ARCH. [] STR. [] ELECT. [X] MECH.			
SUB-CONSULTANT : () ID. () LANDSCAPE. () FAÇADE. () FIRE & LIFE SAFETY. () VT. () IT AV. () SIGNAGE & WAY FINDER. () LIGHTING. () POOL & WATER FEATURE. () SECURITY ACCESS. () ACOUSTIC DESIGN. () GREEN BUILDING. () OTHERS			
Item Description	Chilled Water Valves		(Tick the Related Box)
Specs. Reference	MEP Works Specification Mechanical - Section 230523 General Duty Valves for HVAC Piping, Section 232113 Hydronic Piping		☐ Vendor's Technical Literature
BOQ Reference	Bill No. 10.4 , Bill No. 9.4		☒ Compliance Statement
Drg. Reference	WM-MH-400,WM-MW-099,100,101,102,103,104; WM-MW-T1-101,116,136,137,155,163,164;WM-MW-T2-101,116,136,137,158,160,WM-MW-T3-101,116,131,132,150,152;WM-MH-T1-400,401,402,403,404,405;WM-MH-T2-400,401,402,403,404,WM-MH-T3-400,401,402,403,404		☒ Previous Test Results
Material Specified/ Country of Origin	Chilled Water Valves N/A		☒ Copy of the Related Specs.
Material Proposed/ Country of Origin	Chilled Water Valves ITALY		☒ List of Previous Projects Done
Manufacturer/ Local Supplier	VALVE IT / FLUIDTECH FZE		☒ Samples
Reason for Alternative	N/A		☐ Guarantee
GBR	Not Required		☐ Green Building Compliance required
Remarks/Location	Downtown Views II, Dubai UAE		☐ Others (specify)
<u>Main Contractor's Statement</u> <i>We certify that the material submitted herewith has been reviewed in detail and is in full compliance with the contract drawings, design requirement and specifications except as otherwise stated here above. The material submission shall be to the satisfaction of the Engineer that the material offered is equal or superior to and fully complies with the material specified in the contract's technical specification.</i> Main Contractor Signature : Date : 19/03/19			

Sub-Consultant- WME Comments :



- 1.No objection subject to strict compliance to 'Reply by Vendor / Contractor' for the comments on previous submission.
2. "Contractor" to sign & stamp on the 'Reply by Vendor / Contractor Sheet'.
3. The 5 years 'Guarantee' shall be in the name of 'Emaar'. The exact details shall be shared.


24-3-2019

ARCHGROUP Comments :

STATUS of Approval :

Status A	Status B	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator	MEP Manager  25-03-19	 Resident Engineer
---------------------	---	--

ENGINEER PROJECT DIRECTOR :

Employer's Consent Required (Review by exception only): [] Yes [] No

Emaar MEP : Material Recommended ☐ / Rejected ☐


Contractor to comply with Consultant comments.

 K H A T I B & A L A M I	 T A V Construction	 E M A A R	Material Submittal	No. Revision No. Revision Date Approved by	F02-QP9.1-UAE 1 Oct. 2017 Nik Rowley
Project : A2/A3 The Address Residences Dubai Opera			Ref No. : A23-EFE-MAT-M-00158		
Project Management: MACE			Date: 24-Jan-19 Revision: 00		
Contractor : TAV Construction			Contract No. : T17/004		
FROM : EFECO			TO : Khatib & Alami		

19	Photographs	N/A	
20	Physical loose sample/mockup/sample application	N/A	

Note: IF NO, please specify reasons within the document, signed off and stamped by Contractor's PM.

Material Description :	CHW Valves - General (Alternative)
Location / Area :	As per shop drawings
Drawing Ref. :	
Specification Ref. :	23 05 23
Manufacturer / Supplier :	VALVE IT
Company Name :	
Country of Origin :	Italy
Local Agent :	Fluid Tech FZE
Delivery :	
Production Period :	
Total Delivery Time :	
Expected Date of Delivery on Site :	
Time Required at Site:	

CONTRACTOR:
 NAME: Mr. CONFIDENTIAL SIGNATURE:  DATE: 24 Jan, 2019

Engineer's Comment:
 1. Refer to attached EMAAR as well as K & A comments.
 2. Motorized Butterfly valve is not accepted, it has to be submitted under BMS scope from the same vendor of BMS system.

NAME : Ahmad AlQassab SIGNATURE :  DATE : 26-02-2019

FOR ENGINEER'S USE ONLY

☐ (A) Proceed
☒ (B) Proceed as Noted
☐ (C) Revise and Resubmit

Required:

☐ Samples
☐ Test Certificate
☐ Original Brochure
☐ Manufacturer's Guarantee
☐ More Information
☐ (D) Rejected Material
☐ (E) For Information only;
 Review not required

FOR OWNER'S REPRESENTATIVE/PROJECT MANAGER USE ONLY

☐ Approved
☒ Approved As Noted
☐ Rejected

This approval does not relieve the Contractor from its obligations outlined in the Contract documents

DISTRIBUTION :

Original :	☐ CONTRACTOR
Copies :	☐ OWNER ☐ K & A

F02-QP9.1-UAE, Rev. 01, Oct. 2017

RECEIVED ON

21 AUG 2017

26 SEP 2017

Page 1/1

COMMENTS SHEET (MSS)

A	NO COMMENT	B	COMMENTS AS NOTED	C	UNACCEPTABLE, RE-SUBMIT
---	------------	---	-------------------	---	-------------------------

DESCRIPTION

ETS ROOM AND PUMP ROOM VALVES

Project: MBR - Mulberry Heights Job No: J351

MSS No.: M-129 Rev: 02

Contractor: M/s ECC Issued Date:

Submittal Issued by: M/s UME

Requested

Response Date:

(Minimum period from issue date as per the contract)

05.09.2017

Issued to: (tick as appropriate)

Copies

Copied to: (tick as appropriate)

Copies

Architect

Architect

Structural Engineer

Structural Engineer

MEP Engineer

2 HARD COPIES

MEP Engineer

Other

Other

RECEIVED Time at

20 SEP 2017

BREWER SMITH

BREWER GULF

20 AUG 2017

UNITED MASTERS
20.08.2017

CONFIDENTIAL

Sr. Project Manager - ECC
(Signed and Dated Stamp)EMAAR PROPERTIES
PROJECT - MEP DEPT.

28 AUG 2017

CONFIDENTIAL

Projects Director - UME

SAMPLE

LITERATURE

SAMPLE AVAILABLE
AT SITE

OTHER



material/drawing/document is for the purpose of ascertaining conformity with the scope, concept, profiles and general arrangements only. The review shall not be construed to mean that the Architect/Engineer accepts that installation detail responsibility for which will remain with the Contractor. The Contractor is responsible for any errors or omissions in the material sample/drawing/document and for meeting the requirements of the Contract documents.

PR
EMAAR

25 SEP 2017 2:02

MFR / AGENT

MFR / AGENT

TOP RATED TECHNICAL SERVICES

MAKE / MODEL

NO COMMENT

MAKE / MODEL

VALVE IT

SPEC REF

COMMENTS AS NOTED

SPEC REF

230523

NOTICE OF VARIATION

UNACCEPTABLE, RE-SUBMIT

REASON FOR ALTERNATIVES:

COMMENTS:

MA:- Refer to the comments on attachments 1 page only.

Refer the below comments need to consider with accordingly

Signed:

23.08.17

Company:

Status:

Signed:

Date:

Client's Signature:

Date:

19/9/17



DUBAI HILLS ESTATE
DEVELOPMENT
Mulberry Heights



Date	18 th September 2017
Submittal no.	M-129
Revision	02
Subject	ETS Room and Pump Room Valves
Status	B – Approved As Noted

Comments:

As per Contractor clarification regarding project vendors, the proposed manufacturer is approved only for this particular job subject to;

1. Extended warranty of 5 years from handover including repair and replacement at any damage.
2. Cost saving should be applied by project QS.
3. Proposed material shall be resourced from country of origin not another country. ✓

Best Regards,
For **Allied Consultants Co.** Dubai Branch

Wass

CONFIDENTIAL

Head of Mechanical Department



NSHAMA TOWN SQUARE DEVELOPMENT DISTRICT COOLING PLANT 01



MATERIAL / EQUIPMENT APPROVAL FORM

Project Title & Contract No: NSHAMA Town Square Development - District Cooling Plant 01 / LOA4829

Main Contractor: Steel Construction Engineering Co

Authorised Signature:

Sub Contractor:

Authorised Signature

Item Description	Y-STRAINER	Ref.No.	SCECO/MS/129
Specs / BOQ Reference.	SECTION 23 21 13	Rev.No.	0
Proposed Material / Equip.	Y-STRAINER	Date	10/05/2017
Manufacturer/Local Supplier	VALVE IT	Required By	
Item Selected From	☐ Project List ☐ Alternative (if Yes, Confirm reason)		
Discipline	☒ Mechanical ☐ Electrical ☐ Others		

Refer to attached comment sheet

EMAAR DISTRICT COOLING OFFICE

24 MAY 2017

RECEIVED

Approval Status

- ☐ A - Approved ☒ B - Approved as Noted ☐ C - Not Approved, Resubmit
☐ D - Incomplete, Resubmit ☐ E - Information & Records

The enclosed submittal has been reviewed and confirmed that it is in compliance with the contractor's drawings and specifications except as otherwise stated here above. The consultant recommends the approval of Emear comments as noted.

Consultant's Signature: [Signature] Date: 10/05/2017

No objection subject to comply with Project requirement

Note: The above comments or approvals do not relieve the contractor from his obligation under the contract to ensure conformance to the specifications, design intent and performance.

EMAAR MEP:

Received by Consultants:

Date:

Date:

ATTACHMENTS (IN SEPARATORS)

- ☒ Vendor's Tech. data sheet with high-lighted selection
☐ Any Deviation from Project Specs. (If "yes" reason for deviation)
☒ Vendor's Confirmation of Country of origin
☒ Vendor's Confirmation of Country of Manufacturer
☐ Copy of Relevant System Description / Sizing calculations.
☒ Copy of compliance to Specifications on original contract documents.
☐ Copy of Schedule of Equipment
☐ Copy of Approved List of Manufactures / Suppliers
☒ Copy of Trade license / ISO / Draft Warranty certificates.
☒ Copy of Relevant Test Certificates / Reports (Third Party & Manufacturer).
☒ Copy of Previous Experience / Project Approvals
☐ Copy of Related Contract Drawing / Sketch / System Schematic.
☐ Copy of Relevant Authority Approvals.
☐ Others (Specify) Sample

- ☐ A - Approved
☒ B - Approved as Noted
☐ C - Not Approved, Resubmit
☐ D - Incomplete, Resubmit
☐ E - Information & Records.

RECEIVED

25 MAY 2017

SCECO Dubai

2:10 PM

24-05-2017



	NSHAMA TOWN SQUARE DEVELOPMENT DISTRICT COOLING PLANT (DCP-01)	
---	---	---

Date	17-05-2017
Submittal no.	SCECO/MS/129
Revision	0
Subject	Y - Strainer
Status	B – Approved as Noted


Comments:

The manufacturer is approved for ETS room only subject to:

1. The material shall not be re-sourced from other country.
2. Warranty shall follow project specification.
3. Contractor to provide drain valve with strainer.

Best Regards,

For Allied Consultants Co. Dubai Branch



CONFIDENTIAL

Head of Mechanical Department





**NSHAMA
TOWN SQUARE DEVELOPMENT
DISTRICT COOLING PLANT 01**



MATERIAL / EQUIPMENT APPROVAL FORM

Project Title & Contract No: NSHAMA Town Square Development - District Cooling Plant 01 / LOA4829

Main Contractor: Steel Construction Engineering Co

Authorised Signature: [Signature]

Sub Contractor: _____

Authorised Signature: _____

Item Description	BUTTERFLY VALVES FOR ETS ROOMS PLOT 15 & 16	Ref.No.	SCECO/MS/145
Specs / BOQ Reference.	SECTION 23 05 23	Rev.No.	1
Proposed Material / Equip.	BUTTERFLY VALVES FOR ETS ROOMS PLOT 15 & 16	Date	30/07/2017
Manufacturer/Local Supplier	VALVE IT - TURKEY / TOP RATED TECHNICAL SERVICES	Required By	
Item Selected From	☐ Project List ☐ Alternative (If Yes, Confirm reason: _____)		
Discipline	☒ Mechanical ☐ Electrical ☐ Others		

CONSULTANT COMMENTS

Refer to attached comment sheet



**ATTACHMENTS
(IN SEPARATORS)**

- ☒ Vendor's Tech. data sheet with high-lighted selection
- ☐ Any Deviation from Project Specs. (If "yes" reason for deviation)
- ☒ Vendor's Confirmation of Country of origin
- ☐ Vendor's Confirmation of Country of Manufacturer
- ☐ Copy of Relevant System Description / Sizing calculations.
- ☒ Copy of compliance to Specifications on original contract documents.
- ☐ Copy of Schedule of Equipment
- ☐ Copy of Approved List of Manufactures / Suppliers
- ☒ Copy of Trade license / ISO / Draft Warranty certificates.
- ☒ Copy of Relevant Test Certificates / Reports (Third Party & Manufactured).
- ☒ Copy of Previous Experience / Project Approvals
- ☐ Copy of Related Contract Drawing / Sketch / System Schematic.
- ☒ Copy of Relevant Authority Approvals.
- ☐ Others (Specify) Sample

Approval Status

- ☐ A - Approved
- ☒ B - Approved as Noted
- ☐ C - Not Approved, Resubmit
- ☐ D - Incomplete, Resubmit
- ☐ E - Information & Records

The enclosed submittal has been reviewed and confirmed that it is in compliance with the contractor's drawings and specifications except as otherwise stated here above. The consultant recommends the approval of Emaar comments as noted.

Consultant's Signature: [Signature] Date: 01/08/2017

EMAAR COMMENTS

No technical objection subject to:
1- certificate of origin to be provided upon delivery to the site.
2- cost saving to be provided if applicable.

Note: The above comments or approvals do not relieve the contractor from his obligation under the contract to ensure conformance to the specifications, design intent, and performance.

EMAAR MEP: [Signature]

Date: 6/8/17

Received by Consultants: [Signature]

Date: _____



4:37 p.m



**NSHAMA TOWN SQUARE
DEVELOPMENT
DISTRICT COOLING PLANT (DCP-01)**



Date	31.07.2017
Material Submittal no.	SCECO/MS/145
Revision	1
Subject	Butterfly Valves for ETS Rooms Plot 15 and 16
Status	B – Approved As Noted

Comments:

1. Conditional approval only for this ETS room.
2. Subject to EMAAR approval.

**Best Regards,
For Allied Consultants Co. Dubai Branch**

CONFIDENTIAL an

Head of Mechanical Department





SITE TRANSMITTAL of
Shop Drawings, Materials, etc.

TRANSMITTAL NO : B1-B2/RCC/P/MAS/003

DATE: 14-Mar-19

To: KEO International Consultants

PROJECT	DISCIPLINE	OWNER	CONTRACTOR
OPERA DISTRICT PLOTS B1B2	PLUMBING	EMAAR DEVELOPMENT PJSC	RCC

WE ARE SENDING HERewith THE DRAWINGS / DOCUMENTS / SAMPLES LISTED BELOW
FOR YOUR REVIEW.

ITEM NO.	DRW., SPEC. OR BOQ. REF	GENERAL DESCRIPTION AND REVISION DETAILS	TYPE (i)	COPIES	ACTION CODE (ii)
1	PH1-PW-B1B2 201-00-SC 15-6448-DXB-DES-ADM-SPE-0009 22 0523	PLUMBING VALVES	MD	1 ORIGINAL + 1 CD	B

We certify that the items submitted herewith have been reviewed in detail and are in strict conformance with the Contract Drawings and Specifications except as otherwise stated.

CONTRACTOR :

RECEIVED BY KEO :

DATE:

DATE:

KEO'S REMARKS :

- 1- Gate valve 65 mm and above shall be non-rising stem as specified.
- 2- Strainer 50 mm and below shall be PN 25 as specified.
- 3- Strainer DN 65 and larger shall be cast iron epoxy coating with drilled and tapped cap complete with drain cock as specified.
- 5- Valves for transfer line to tower shall be PN 20 minimum.
- 6- Schedule of valves to be updated after approval of shop drawings.
- 7- Certificate of origin confirming Italy origin to be submitted upon delivery.

Corrections or comments made relative to submittals during this review does not relieve the contractor from compliance with the requirements of his Contract, drawings and specifications. This review is only in respect of general conformance with the design intent of the project and general compliance with the information given in the Contract documents. The contractor remains responsible, among other things, for the design of the project or such parts of the project he has design responsibility for (if design forms part of the Contract), for confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner, all in accordance with the Contract.

KEO CM / RE

CONFIDENTIAL

RECEIVED BY CONTRACTOR :

DATE:

DATE:

- (i) TYPE: SD: Shop Drawings
SM: Sample
GT: Guarantee
MD: Manufacturer's Data
CT: Certificates
OT: Others

(ii) ACTION CODE:

- A: No objection
B: No objection as Noted
C: Rejected & Resubmit

PROJECT: B1 AND B2 EMAAR RESIDENTIAL TOWER



CLIENT :	EMAAR DEVELOPMENT PJSC
PROJECT MANAGER:	MACE INTERNATIONAL
SUPERVISING CONSULTANT:	KEO INTERNATIONAL
MAIN CONTRACTOR:	CHINA STATE CONSTRUCTION ENG.CORP. (MIDDLE EAST) (L.L.C.)
SUB CONTRACTOR:	RELIANCE CONTRACTING COMPANY



MATERIAL APPROVAL SHEET (MAS)

Planned Submission Date : 03/25/2019	Actual Submission Date: 03/14/2019
Submittal No. B1-B2-RCC-P-MAS-003	Rev. 00 Date: 03/14/2019
Releasing Date	Due Date:
Previous Submittal Ref No.	Rev. Date: <i>4/3/19</i>
Originator : RELIANCE CONTRACTING COMPANY	Sign of Originator:

Material Detail

List of Enclosure

Item Description	PLUMBING VALVES	(Tick the Related Box)
Specs. Reference 15-6448-DXB-DES-ADM-SPE-0009 22 0523	PH1-PW-B1B2-201-00-SC	☒ Vendor's Technical Literature
BOQ Reference	-	☒ Compliance Statement
Drg. Reference	PH1-PW-B1B2-201-00-SC	☐ Previous Test Results
Material Specified/ Country of Origin	PLUMBING - GENERAL REQUIREMENTS FOR VALVE & ANCILLARIES	☒ Copy of the Related Specs.
	N/A	
Material Proposed/ Country of Origin	VALVE IT FOR PLUMBING VALVES	☒ List of Previous Projects Done
	ITALY	
Make	VALVE/ IT	☐ Compliance to Specification
Manufacturer/ Local Supplier	VALVE IT / FLUIDTECH FZE (FULLY OWNED SUBSIDIARY OF VALVE	☒ Samples
Reason for Alternative	N/A	☐ Guarantee
GBR	N/A	☐ Green Building Compliance
Remarks/Location	VALVE FOR WATER SUPPLY	☒ Others (specify) approved

Main Contractor's Statement

We certify that the material submitted herewith has been reviewed in detail and is in full compliance with the contract drawings, design requirement and specifications except as otherwise stated here above. The material submission shall be to the satisfaction of the supervising consultant that the material offered is equal or superior to and fully complies with the material specified in the contract's technical specification.

Main Contractor Signature :

Date : 4/3/19

~~Sub-Consultant~~ _____ Comments :

KEO Comments :

- 1- Gate valve 65 mm and above shall be non-rising stem as specified.
- 2- Strainer 50 mm and below shall be PN 25 as specified.
- 3- Strainer DN 65 and larger shall be cast iron epoxy coating with drilled and tapped cap complete with drain cock as specified.
- 5- Valves for transfer line to tower shall be PN 20 minimum.
- 6- Schedule of valves to be updated after approval of shop drawings.
- 7- Certificate of origin confirming Italy origin to be submitted upon delivery.

STATUS of Approval :

Status A	Status B	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator	MEP Manager	Resident Engineer
---------------------	-------------	-------------------

CONFIDENTIAL**SUPERVISING CONSULTANT PROJECT DIRECTOR :**

Employer / PMO's Consent Required (Review by exception only): [] Yes [] No

Emaar MEP : Material Recommended ☐ / Rejected ☐Emaar Security / IT: Material Recommended ☐ / Rejected ☐Other Emaar Departments: Material Recommended ☐ / Rejected ☐Emaar Development Director : Material Recommended ☐ / Rejected ☐Project Manager: Material Recommended ☐ / Rejected ☐

Corrections or comments made relative to submittals during this review do not relieve the Contractor from compliance with the Contract requirement's, specifications and design concept. This check is for review of general project requirements only.

Main Contractor Received:
Date & Sign

 EMAAR	 DAR CONSULT DAR	EMI LATES HILLS DEVELOPMENT THE HILLS: MAIN CONTRACT WORKS	 AGGCIC
MEP MATERIAL / EQUIPMENT APPROVAL FORM			
Project Title & Contract No: The Hills : Main Contract Works			
Main Contractor: AGGCIC		Authorised Signature: <i>[Signature]</i> PM: CONFIDENTIAL	
Sub Contractor: MMC-HMCW-MTF-MEP-0063 REV.05		Authorised Signature: <i>[Signature]</i>	
Item Description	Valves / Plumbing Valves	Ref.No.	AGGCIC-HMCW-MTF-MEP-0063
Specs / BOQ Reference.	PART A - SECTION 4	Rev.No.	06
Proposed Material / Equip.	Valve IT	Date	03-06-17
Manufacturer/Local Supplier	M/s. Top Rated Technical Services LLC	Required By	10-06-17
Item Selected From	☐ Project List ☐ Alternative (If Yes, Confirm reason : ... (Not Specifically mentioned in the Consultant Vendor List)		
Discipline	☒ Mechanical ☐ Electrical ☐ Others		
CONSULTANT COMMENTS * Although it is not From Vendor List, it is approved as it is technically OK. * Subject to client approval EMAAR PROPERTIES PJSC PROJECTS - MEP DEPT. 08 JUN 2017 RECEIVED <i>Wael</i>		(IN SEPARATORS) ☐ Vendor's Tech. data sheet with high-lighted selection ☐ Any Deviation from Project Specs. (If "yes" reason for deviation) ☒ Vendor's Confirmation of Country of Origin ☐ Vendor's Confirmation of Country of Manufacturer ☐ Copy of Relevant System Description / Sizing calculations ☒ Copy of compliance to Specifications on original contract documents. ☒ Copy of Schedule of Equipment ☐ Copy of Approved List of Manufacturers / Suppliers ☒ Copy of Trade license / ISO / Draft Warranty certificates. ☒ Copy of Relevant Test Certificates / Reports (Third Party & Manufacturer). ☒ Copy of Previous Experience / Project Approvals ☐ Copy of Related Contract Drawing / Sketch / System Schematic. ☒ Copy of Relevant Authority Approvals ☒ Others (Specify)	
Approval Status ☐ A - Approved ☒ B - Approved as Noted ☐ C - Not Approved, Resubmit ☐ D - Incomplete, Resubmit ☐ E - Information & Records			
The enclosed submittal has been reviewed and confirmed that it is in compliance with the contractor's drawings and specifications except as otherwise stated here above. The consultant recommends the approval of Emaar comments as noted.			
Consultant's Signature: <i>[Signature]</i>		Date: 06 JUN 2017	
EMAAR COMMENTS <i>Refer attached</i>		☐ A - Approved ☒ B - Approved as Noted ☐ C - Not Approved, Resubmit ☐ D - Incomplete, Resubmit ☐ E - Information & Records	
Note: The above comments or approvals do not relieve the contractor from his obligation under the contract to ensure conformance to the specifications, design intent, and performance.			
EMAAR MEP: <i>[Signature]</i>		Date: 15/06/2017	
Received by Consultants: <i>[Signature]</i>		Date: 06 JUN 2017	

DAR CONSULT
THE HILLS: MAIN CONTRACT WORKS
06 JUN 2017
RECEIVED

DOCUMENT TRANSMITTAL

To

M/s. LEADERS FORT CONTRACTING LLC
PO Box. 91766
Abu Dhabi, UAE

From:

Tabreed - National Central Cooling Co. (PJSC)
Post Box 29478
Masdar, City, Abu Dhabi

Submittal Ref. TPM-ETN-TDM CINEMA-001
Date: 28 March 2023

Rev.0

Project: Design, Supply & Installation of Chilled Water ETS in TDM Reel Cinema
Contract:

Documents Description

Sl. No.	Document No.	Description	Approved Status
1	LFC-M132-M-MAR-0011 R0	Material Submittal for Primary Chilled Water Valves	Code B
		Refer to attached CRS sheet	

Type of Submittal:

Discipline:

PROJECT DOCUMENTS		O AND M MANUALS		GENERAL	√
SHOP DRAWING		MATERIAL SUBMITTAL	√	CIVIL / STRUCTURAL	
PRE-QUALIFICATION		METHOD STATEMENT		MECHANICAL	
PROGRAMME		OTHERS		ELECTRICAL	
AS BUILT DRAWINGS		RFI/MIR		INSTRUMENTATION	

Submittal Review Status:

Comments:

Code A : Approved

Code B : Approved with comments. Manufacturing/Procurement or Construction activity can proceed

Code C: Major Comments. Revise & Re-submit. Manufacturing/Procurement or Construction activity cannot proceed.

Code D: Rejected

For and Behalf of Tabreed



Project Manager

CONFIDENTIAL

Acknowledgment:

Date:

Signature:

		COMMENTS RESOLUTION SHEET [CRS]				
CONTRACT NUMBER		-			DATE: 28 March 2023	
PROJECT TITLE		Design, Supply & Installation of Chilled Water ETS in TDM Reel Cinema				
TABREED EXTERNAL TRANSMITTAL REFERENCE		TPM-ETN-TDM CINEMA-001 R0			CONTRACTOR REF.	
DOCUMENT NUMBER		LFC-M132-M-MAR-0011 R0				
DOCUMENT TITLE		Material Submittal for Primary Chilled Water Valves				
Rev.0		Rev.01			Rev.02	
No.	Tabreed Comments	CONTRACTOR RESPONSE	Tabreed Comments	CONTRACTOR RESPONSE	Tabreed Comments	CONTRACTOR RESPONSE
1	No objection for the proposed brand ValveIT.					
2	Vendor to submit the coating certificate, and Material test certificates confirming the construction of the materials as per the compliance.					
3	Sizes to be as per the approved design.					
4	Ensure to obtain further approval of Emaar/EFM/Consultants in the project.					
	Status: Code B - Approved with comments					



MATERIAL SUBMITTAL

Project	DESIGN, SUPPLY & INSTALLATION OF CHILLED WATER ETS IN TDM REEL CINEMA		
Client	EMAAR MALLS MANAGEMENT LLC	Ref. No.	LFC-M132-M-MAR-0011
Consultant	WSP	Revision	0
Contractor	LEADERS FORT CONTRACTING L.L.C.	Date	13-Mar-23

Description :

Material Submittal for Primary Chilled Water Valves
Brand: ValveIT

Submitted by Contractor:

Signature & Stamp:

Received by Client:

Signature & Stamp:

Name: **CONFIDENTIAL**

Name:

Date: 13-Mar-2023

Date:

Client Engineer's Instructions and Comments:

Date:

The above submittal is: ☐ Approved ☐ Approved as Noted ☐ Revise & Resubmit ☐ Rejected

Consultant Engineer's Instructions and Comments:

Date:

The above submittal is: ☐ Approved ☐ Approved as Noted ☐ Revise & Resubmit ☐ Rejected

Client Engineer

Signature & Stamp:

Consultant Engineer

Signature & Stamp:

Name:

Date:



EMAAR



Heat & Power

A013

Material Approval Request (MAR)

Contract Title:	A013, PALACE RESIDENCE NORTH AT DCH, DUBAI		
Contract/ LOA No.:		Plot No.	4154946
Employer:	EMAAR	Building Permit	B2205998
Engineer:	ARCHGROUP CONSULTANTS		
Main Contractor:	AL SAHEL CONTRACTING CO.LLC	Unifier Ref:	
Reference No.:	J267-H&P-MAT-PL-0021	Revision:	002
Date:	26/02/2024		

Tick the relevant items below:

☐ Civil/Structural ☐ Architectural ☒ MEP ☐ Landscaping ☐ Others: _____

We are sending herewith the Documents/ Drawings / Samples listed below.

Material Information

Name of Product:	PLUMBING VALVES
Location of use:	ALL FLOORS
Name Manufacturer:	ValveIT
Source / Country of Origin:	ITALY
Name Local Agent/Supplier:	FLUID TECH FZE
Specification / Control Document Reference:	Mechanical Specification Section 04
Alternative to Specified product:	☐ Yes ☒ No
Reason for use of alternate product:	NA
Cost Impact:	☐ Yes ☒ No
Time Impact:	☐ Yes ☒ No
Description of Attachments (Spec., Brochure, Sample etc.):	Specification, Brochure,
Description of Samples:	As Per Previous Approved Samples

Compliance Statement: The Contractor hereby confirms that the submitted items have been reviewed in detail and are correct and in accordance with the Contract Documents except otherwise stated.

Compliance with local Authorities Regulations:

PD/PM (H&P)	MEP Manager (ASCC)	PD/PM (ASCCB 2024)	QA/QC (ASCC)	Date:
Name: CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL		
Signature:				

Engineer Comments:

-Refer the comments enclosed in the attached

Engineer Review Code:

☐ A- Approved
☐ B- Approved_As_Noted
☐ C- Not_Appeared

Resubmit

☐ D- Incomplete_Resubmit
☐ E- Information_Record

Engineer's Representative: Sr.RE/Project Director

Date: 11/03/2024

Employer Comments:

Comply with EMEP and Consultant Comments

Employer

Date: 11/03/2024

Action Code:

A - ☐
B - ☒
C - ☐
D - ☐
E - ☐

Distribution: ☐ Contractor (Original) ☐ PMO ☐ Engineer

NOTE: The Engineer's approval shall not in any way relieve the Contractor of his obligation under the Contract. The Contractor shall be solely responsible for the soundness and the correctness of the submitted materials and documents.

PROJECT TITLE:

GREENSIDE RESIDENCE (DHE-PA7.0007), PLOT NO. 6316882,
DUBAI HILLS ESTATE - UAE

MATERIAL SUBMITTAL

EMAAR

al wasal
al jadeed
consultants

ASIA PRIME GENERAL CONTRACTING CO. LLC



Ref. No: MS-MEC-056

Rev: 01

Date: 25-Sep-24

Submittal Title : Plumbing Valves

Item No.	Material Description	Location
1	Plumbing Valves (Gate Vales, Check Valves, Y-Strainer, DRV, Angle Valves) (Brand: ValveIT)	PROJECT: Green Side Residences AWAJ Site Office
Manufacturer	valveIT	Distribution
Country of Origin	Italy	Action
Applicable Standards	As attached	Info
Project specs. Ref.	Mechanical Specification - Section 03	Client
BOQ Ref.	Bill 2 Mechanical 1382.	AWAJ HO
Location of use	Water Supply System All floors	RE
Technical Details submitted as	: ☒ Attachment ☐ Catalogue	Architect
Sample Provided	: ☒ Yes ☐ No	Struct Engr.
Availability of Material	: ☐ Local ☒ Import	Civil Engr.
Lead Time Required	: ☒ Yes ☐ No	Planning Engr.
Time of Delivery to Site: As progress		Safety Engr.
Supplier Details	Company Name & Address: Altura Equipment and Machinery Trading LLC Telefax - 43373317	Mech Engr.
Compliance with Project Specifications	: ☒ Yes ☐ Alternative (please fill below)	Elec Engr.
ALTERNATIVE MATERIAL		
Time Implication of Alternatives	: ☒ No ☐ Yes	Civil Insp.
Cost Implication of Alternatives	: ☒ No ☐ Yes	Arch Insp.
Reasons for Alternative (include supporting documents, if any): As per consultant requirement		Others

The above mentioned material is submitted for your review / approval.

Submitted by: M/s MEPCO Electromechanical Works LLC	Subcontract's Representative CONFIDENTIAL	Signature 	Date 25-Sep-24
Submitted by: M/s Asia Prime General Contracting Co.	Contractor's Representative CONFIDENTIAL	Signature 	Date 25-Sep-24

CONSULTANT'S COMMENTS:

Refer to comments on the attached sheet

(B)

Engineer's Representative

Name:

Signature

Date:

The aforementioned material has been -

- ☒ A - Approved as submitted
☐ B - Approved as noted incorporate & proceed
☐ C - Revise & Re-submit before work proceeds
☐ D - Rejected

Received by Contractor

Contractor's Representative

Signature

Date

Distribution:

☐ Employer☐ Consultant☐ Contractor

PROJECT: Greenside Residence

AWAJ Site Office

01 OCT 2024

RECEIVED

BY: Dc

TIME: 11 AM

PROJECT TITLE:

GREENSIDE RESIDENCE (DHE-PA7.0007),
PLOT NO. 6316982, DUBAI HILLS ESTATE -
UAE

MATERIAL SAMPLE TAG

EMAAR



DUBAI HILLS
ESTATE



al wasi
al jadeed
consultants

**Submittal Ref. No:****MS-MEC-056****Date :** 25-Sep-24**Material Description****Rev: 01****Plumbing Valves****Manufacturer:** valveIT**Location of use:** Water Supply System All floors**Subcontractor's Representative****CONFIDENTIAL**

Signature

25-Sep-24

Contractor's Representative**CONFIDENTIAL**

Signature

25-Sep-24

Status.**Engineer's Representative****Name:****Signature****Date :**

- ☒ A - Approved as submitted
☐ B - Approved as noted incorporate & proceed
☐ C - Revise & Re-submit before work proceeds
☐ D - Rejected

Engineer's Comments:**APPROVED.****Status.****Client's Representative****Name:****Signature****Date :**

- ☐ A - Approved as submitted
☐ B - Approved as noted incorporate & proceed
☐ C - Revise & Re-submit before work proceeds
☐ D - Rejected

PROJECT TITLE:GREENSIDE RESIDENCE (DHE-PA7.0007), PLOT NO. 6316982,
DUBAI HILLS ESTATE - UAE**MATERIAL SUBMITTAL****EMAAR**


Ref. No: MS-MEC-068

Rev: 01

Date: 28-Sep-24

Submittal Title : Automatic Air Vents

Item No.	Material Description	Location
1	Automatic Air Vents (Brand - Valvet)	
Manufacturer: Valvet Country of Origin: Italy Applicable Standards: As attached Project specs. Ref.: Mechanical Specification -Section 03 BOQ Ref.: Bill No 2-Mech 1360 Location of use: Chilled water system , Water supply system as per shop drawing Technical Details submitted as : ☒ Attachment ☐ Catalogue Sample Provided : ☒ Yes ☐ No Availability of Material : ☐ Local ☒ Import Lead Time Required : ☒ Yes ☐ No Time of Delivery to Site: As progress		PROJECT: Green Side Residences AWAJ Site Office Distribution Client AWAJ HO Architect Struct Engr. Civil Engr. Planning Engr. Safety Equipment and Machinery Trading LLC Mech. Engr. info@aituramachineries.com Elec. Engr. QS Civil Insp. Admin Insp. Others
Supplier Details Company Name & Address: Telefax - 43373317 Compliance with Project Specifications : ☒ Yes ☐ Alternative (Please fill below)		
ALTERNATIVE MATERIAL Time Implication of Alternatives : ☒ No ☐ Yes Cost Implication of Alternatives : ☒ No ☐ Yes Reasons for Alternative (include supporting documents, if any): As per consultant requirement		
The above mentioned material is submitted for your review / approval.		
Submitted by: M/s MEPCO Electromechanical Works LLC		Subcontract's Representative CONFIDENTIAL Date 28-Sep-24
Submitted by: M/s Asia Prime General Contracting Co.		Contractor's Representative CONFIDENTIAL Date 28-Sep-24
CONSULTANT'S COMMENTS: Refer to comments on the attached sheet (3)		
The aforementioned material has been - Engineer's Representative Name: SAIF AL DAWOOD Signature: [Signature] Date: 03/10/24 ☐ A - Approved as submitted ☐ B - Approved as noted incorporate & proceed ☐ C - Revise & Re-submit before work proceeds ☐ D - Rejected		
Received by Contractor	Contractor's Representative	Signature
Distribution: ☐ Employer ☐ Consultant		Date



PROJECT TITLE:

GREENSIDE RESIDENCE (DHE-PA7.0007),
PLOT NO. 6316982, DUBAI HILLS ESTATE -
UAE

MATERIAL SAMPLE TAG

EMAAR

DUBAI HILLS
ESTATE**Submittal Ref. No:****MS-MEC-068****Date :** 28-Sep-24**Material Description****Rev:** 01**Automatic Air Vents****Manufacturer:** ValveIT**Location of use:** Chilled water system , Water supply system as per shop drawing**Subcontractor's Representative****CONFIDENTIAL**

Signature

28-Sep-24

Contractor's Representative**CONFIDENTIAL**

Signature

28-Sep-24

Status.**Engineer's Representative****Name:** *Salim J. J. J.***Signature:** *[Signature]***Date :** *03/10/24*☒ A - Approved as submitted☐ B - Approved as noted incorporate & proceed☐ C - Revise & Re-submit before work proceeds☐ D - Rejected**Engineer's Comments:***APPROVED***Status.****Client's Representative****Name:** **CONFIDENTIAL****Signature:****Date :**☐ A - Approved as submitted☐ B - Approved as noted incorporate & proceed☐ C - Revise & Re-submit before work proceeds☐ D - Rejected

PROJECT TITLE:

GREENSIDE RESIDENCE (DHE-PA7.0007), PLOT NO. 6316882,
DUBAI HILLS ESTATE - UAE

MATERIAL SUBMITTAL

EMAAR



Ref. No: MS-MEC-055

Rev: 01

Date: 25-Sep-24

Submittal Title: Chilled Water Valves

Item No.	Material Description	Location
1	Chilled Water Valves (Brand: ValveIT)	PROJECT: Green Side Residences AWAJ Site Office
Manufacturer	valveIT	Distribution
Country of Origin	Italy	Client
Applicable Standards	As attached	AWAJ HO
Project specs. Ref.	Mechanical Specification -Section 03	RF
BOQ Ref.	Bill 2 Mechanical 1382.	Architect
Location of use	Chilled water network all floors	Struct Engr.
Technical Details submitted as	☒ Attachment ☐ Catalogue	Civil Engr.
Sample Provided	☒ Yes ☐ No	Planning Engr.
Availability of Material	☐ Local ☒ Import	Safety Engr.
Lead Time Required	☒ Yes ☐ No	Mech Engr.
Time of Delivery to Site: As progress		Elec. Engr.
Supplier Details	Company Name & Address: Altura Equipment and Machinery Trading LLC Telefax: 43373317	Email: sales@alturamachineries.com
Compliance with Project Specifications	☒ Yes ☐ Alternative (please fill below)	MS
ALTERNATIVE MATERIAL		Civil Insp.
Time Implication of Alternatives	☒ No ☐ Yes	Arch Insp.
Cost Implication of Alternatives	☒ No ☐ Yes	Others
Reasons for Alternative (include supporting documents, if any): As per consultant requirement		

The above mentioned material is submitted for your review / approval.

Submitted by: M/s MEPCO Electromechanical Works LLC	Subcontract's Representative CONFIDENTIAL	Signature 	Date 25-Sep-24
Submitted by: M/s Asia Prime General Contracting Co.	Contractor's Representative CONFIDENTIAL	Signature 	Date 25-Sep-24

CONSULTANT'S COMMENTS:

Refer to comments on the attached sheet (9)

Engineer's Representative

Name: SAITHE DADARSignature: [Signature]Date: 02/10/24

The aforementioned material has been -

- ☐ A - Approved as submitted
☒ B - Approved as noted incorporate & proceed
☐ C - Revise & Re-submit before work proceeds
☐ D - Rejected

Received by Contractor

Contractor's Representative

Signature

Date

Distribution:

☐ Employer☐ Consultant☐ Contractor

PROJECT: Greenside Residence

AWAJ Site Office

01 OCT 2024

RECEIVED

BY: DCTIME: 11 AM

PROJECT TITLE:GREENSIDE RESIDENCE (DHE-PA7.0007),
PLOT NO. 6316982, DUBAI HILLS ESTATE -
UAE**MATERIAL SAMPLE TAG**

EMAAR

DUBAI HILLS
ESTATEal wasil
al jadeed
consultants
ASIA
 ASIA PRIME GENERAL CONTRACTING CO. LLC
**Submittal Ref. No:****MS-MEC-055****Date :** 25-Sep-24**Material Description****Rev: 01****Chilled Water Valves****Manufacturer:** valveIT**Location of use:** Chilled water network all floors .**Subcontractor's Representative****CONFIDENTIAL**

Signature

25-Sep-24

Contractor's Representative**CONFIDENTIAL**

Signature

25-Sep-24

Status.**Engineer's Representative****Name:** SAIED HAN**Signature****Date :** 6.3/10/24☒ A - Approved as submitted☐ B - Approved as noted incorporate & proceed☐ C - Revise & Re-submit before work proceeds☐ D - Rejected**Engineer's Comments:**

APPROVED

Status.**Client's Representative****Name:** **CONFIDENTIAL****Signature****Date :**☐ A - Approved as submitted☐ B - Approved as noted incorporate & proceed☐ C - Revise & Re-submit before work proceeds☐ D - Rejected

PROJECT TITLE:GREENSIDE RESIDENCE (DHE-PA7.0007), PLOT NO. 6318882,
DUBAI HILLS ESTATE - UAE**MATERIAL SUBMITTAL****EMAAR**Ref. No: **MS-MEC-076**Rev: **0**Date: **26-Sep-24**Submittal Title : **Biptaps**

Item No.	Material Description	PROJECT: Greenside Residence	Location
1	Biptaps	AWAJ Site Office	
	(Brand - ValveIT)	Distribution	Action Info.
		Client	✓
Manufacturer	ValveIT	AWAJ HQ	
Country of Origin	Italy	RE	
Applicable Standards	As attached	Architect	
Project specs. Ref.	Mechanical Specification -Section 04	Struct Engr.	
BOQ Ref.	Bill No 2-Mech 593	Civil Engr.	
Location of use	Car park areas , Roof and Garbage rooms	Planning Engr.	
Technical Details submitted as	: ☒ Attachment ☐ Catalogue	Safety Engr.	
Sample Provided	: ☒ Yes ☐ No	Mech. Engr.	✓
Availability of Material	: ☐ Local ☒ Import	Elec. Engr.	
Lead Time Required	: ☐ Yes ☒ No		
Time of Delivery to Site:	As progress		
Supplier Details	Company Name & Address: Altura Equipment & Machineries Trading LLC	Civil Engr.	
	Telefax - 43373317	info@alturamachineries.com	
Compliance with Project Specifications	: ☒ Yes ☐ Alternative (please fill below)	Others	
ALTERNATIVE MATERIAL			
Time Implication of Alternatives	: ☒ No ☐ Yes		
Cost Implication of Alternatives	: ☒ No ☐ Yes		
Reasons for Alternative (include supporting documents, if any): As per consultant requirement			

The above mentioned material is submitted for your review / approval.

Submitted by: M/s MEPCO Electromechanical Works LLC	Subcontract's Representative CONFIDENTIAL	Signature 	Date 26/09/2024
Submitted by: M/s Asia Prime General Contracting Co.	Contractor's Representative CONFIDENTIAL	Signature 	Date 26/09/2024

CONSULTANT'S COMMENTS:

Refer to comments on the attached sheet

(B)

The aforementioned material has been -

Engineer's Representative

Name: **SALWA DAWAD**

Signature:

Date: **01/10/24**

☒ A - Approved as submitted

☐ B - Approved as noted incorporate & proceed

☐ C - Revise & Re-submit before work proceeds

☐ D - Rejected

Received by Contractor	Contractor's Representative	Signature	Date
------------------------	-----------------------------	-----------	------

Distribution: ☐ Employer ☐ Consultant ☐ Contractor ☐ Others

PROJECT TITLE:

GREENSIDE RESIDENCE (DHE-PA7.0007),
PLOT NO. 6316982, DUBAI HILLS ESTATE -
UAE

MATERIAL SAMPLE TAG

EMAAR



DUBAI HILLS
ESTATE



al wasil
al jadeed
consultants



ASIA PRIME GENERAL CONTRACTING CO. LLC



MEPCO
MEPCO Electrical Mechanical Works LLC

Submittal Ref. No:**MS-MEC-076****Date :** 26-Sep-24**Material Description****Rev: 01****Biptaps****Manufacturer:** ValveIT**Location of use:** Car park areas , Roof and Garbage rooms**Subcontractor's Representative****CONFIDENTIAL**

Signature

26-Sep-24

Contractor's Representative**CONFIDENTIAL**

Signature

26-Sep-24

Status.**Engineer's Representative****Name:** SAIGAL DASAN**Signature** **Date :** 1/10/24

- ☒ A - Approved as submitted
☐ B - Approved as noted incorporate & proceed
☐ C - Revise & Re-submit before work proceeds
☐ D - Rejected

Engineer's Comments:

APPROVED

Status.**Client's Representative****Name:** **CONFIDENTIAL****Signature****Date :**

- ☐ A - Approved as submitted
☐ B - Approved as noted incorporate & proceed
☐ C - Revise & Re-submit before work proceeds
☐ D - Rejected



APPROVAL FORM

DATE: 25.Apr.2017

HAZARDOUS LIQUID WASTE TREATMENT PLANT
AT JAHWTF

Website : www.veoliawater.com

PROJECT: WTS-2013-04

Veolia Project No: 415086102

Transmittal No: 415086102-VWE-KBR-072

DUBAI MUNICIPALITY
WASTE MANAGEMENT DEPARTMENT
P.O. BOX NO. 67 DUBAI, UAE
PROJECT: WTS-2013-04

Copy with Attachment:

TO:

Dubai Municipality

Copy without Attachment:

Waste Management Department

The following :



Documents



Drawings



Equipment

Are being sent for :



Approval



Information



Request

Review Status Code:



1. Approved – No Further comments, Work may proceed in accordance with the submitted documents.



2. Minor comments to be incorporated – Work may proceed subject to compliance with and incorporated of comments within 8 days.



3. Major comments to be incorporated – Revise & Re-submit.



4. For Information only – Content noted.

SL. No.	DESCRIPTION	DOCUMENT NO.	Rev. No.	Number of	
				Print	Re-print
1.	Valves Technical Submittal (Supplier: ValveIT)	415086102-MSP-014	A	1	

COMMENTS :



Project Manager:

CONFIDENTIAL

Signature:

Date: 25.04.17

Received By : Dubai Municipality

Signature:

Date:



PROJECT NAME: D-106971.1 Refurbishment of ADDC DMS Mezzanine & Service Floors	EMPLOYER:  شركة أبوظبي للتوزيع Abu Dhabi Distribution Co.	MAR No. : 055R1
Status: ☐ APPROVED ☒ APPROVED AS NOTED ☐ REVISE AND RESUBMIT ☐ REJECTED	ENGINEER:  Rafik El-Khoury & Partners Consulting - Engineers	DATE : 13 NOV 2018
PROJECT MANAGEMENT: ☐ APPROVED AS NOTED ☐ REVISE AND RESUBMIT ☐ REJECTED	CONTRACTOR:  شركة أبو حسين للمقاولات. ذ.م.م ABU HUSSAIN CONTRACTING COMPANY LLC	
Signature: <i>Ron A</i> Date: 14/11/2018		

MATERIAL APPROVAL REQUEST (MAR)

Material Description & Type	: VALVES
Drawing Reference	:
Specification Clause	: 15110 BOQ Reference : B3/12, ITEM C TO F
Area of Application	: SERVICE FLOOR/MEZZ FLOOR
Technical Literature Attached	: ☐ YES ☒ NO
ALWEA Vendor List	: ☒ YES ☐ NO
Sample Attached	: ☒ YES ☐ NO
Manufacturer	: VALVEIT
Country of Origin	: ITALY
Local Agent	: M/S FLUID TECH FZE
Type of Shipment	: ☐ LAND ☐ SEA ☐ AIR
Anticipated Period of Delivery from Placing Order	: 6-8 WEEKS
Anticipated Period when Material to be used on Site	:

Rafik El-Khoury & Partners RECEIVED - AD

PROJECT: *ADDC DMS*

LETTER: *13 NOV 2018*

FAX: ☐ NO ☐ YES

EMAIL: ☐ NO ☐ YES

SERIAL NUMBER: *18-11-028*

NAME: _____

The material submitted for approval has been checked for conformity with drawings and specifications and any deviations noted here in:

Originator:	Signature: _____	Date: _____
Contractor's Representative	Signature: _____	Date: 13 NOV 2018

Consultant's Response / Comments

1. The above manufacturer which not in ADWEA Vendor list is approved based on Contractor supply and Compliance of the valves properties with Specification
2. All Valves To be checked By the Engineer upon receipt on site prior to use.
3. warranty Certificate To be submitted upon receipt of materials on site.

Name: CONFIDENTIAL	Signature: <i>Ron A</i>	Date: 14/11/2018
Approval shall not relieve the Contractor of his liabilities under the Contract or constitute authorization of any change to the Contract Documents.		

FOR CONSULTANT USE:	FOR CONSULTANT USE:	FOR CONTRACTOR USE:

PROJECT: ROVE LA MER HOTEL

ROVE	CLIENT :	ROVE HOTELS	
	CONSULTANT :	ARCHGROUP	
	MAIN CONTRACTOR :	TROJAN GENERAL CONTRACTING L.L.C. (TGC)	
	SUB CONTRACTOR :	NATIONAL PROJECT & CONSTRUCTION L.L.C. (NPC)	

MATERIAL SUBMITTAL (MAS)

Planned Submission Date : 25-Apr-2019	Actual Submission Date: 25-May-2019
Submittal No. MAS-MEP-PL-082	Rev. 00 Date: 25-May-2019
Previous Submittal Ref No. N/A	Rev. N/A Date: N/A
Originator : CONFIDENTIAL	Sign of Originator : 

Material Detail

List of Enclosure

Item Description	Plumbing Valve	(Tick the Related Box)
Specs. Reference	Section 6 – Plumbing Works	Vendor's Technical Literature
BOQ Reference	N/A	✓ Compliance Statement
Drg. Reference	IFC 00-MEP-MECH-PL, IFC 00-MEP-MECH-WS	✓ Previous Test Results
Material Specified/ Country of Origin	N/A	✓ Copy of the Related Specs.
	N/A	✓ List of Previous Projects Done
Material Proposed/ Country of Origin	Plumbing Valve	
	Italy	
Manufacturer/ Local Supplier	VALVE IT - M/s. Fluid Tech FZE LLC – U.A.E.	✓ Samples
Reason for Alternative	N/A	✓ Warranty
Remarks		Others (specify)

Main Contractor's Statement

We certify that the material submitted herewith has been reviewed in detail and is in full compliance with the contract drawings, design requirement and specifications except as otherwise stated here above.

Main Contractor Signature : 

Date : 26/5/2019

Sub-Consultant:

Comments :

Contd...

ARCHGROUP Comments :

- Refer Comments as enclosed!


03/6/19

STATUS of Approval :

Status A	Status B	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator 	MEP Manager 	Resident Engineer/PM 
ENGINEER'S REPRESENTATIVE/ AREA MANAGER :		

Employer's Consent :

MEP : - Refer Enaar Comments attached.

Security / IT:

Other Departments :

ROVE HOTELS:

Project Director: Material Recommended ☐ / Rejected ☐

CONFIDENTIAL

Corrections or comments made relative to submittals during this review do not relieve the Contractor from compliance with the Contract requirement's, specifications and design concept. This check is for review of general project requirements only.

Main Contractor Received :

Date & Sign

ROVE LA MER
26 MAY 2019
RECEIVED

ROVE
15 JUN 2019
RECEIVED

PROJECT: ROVE LA MER HOTELS

	CLIENT :	ROVE HOTELS		
	CONSULTANT :	ARCHGROUP		
	MAIN CONTRACTOR :	TROJAN GENERAL CONTRACTING LLC		
	SUB CONTRACTOR / MANUFACTURER :	National Projects & Construction LLC		

SAMPLE TAG

Submittal No. MAS-MEP-PL-082		Rev. 00	Date: 25-May-2019
Previous Submittal Ref No.		Rev.	Date:
Subcontractor / Manufacturer	Plumbing Valve	MEP Manager:	
Technical Manager:		QA/QC Manager:	

We are sending herewith the Material Samples as listed below :

VALVE IT - M/s. Fluid Tech FZE LLC – U.A.E. – Plumbing Valve			
Location to be used :		IFC 00-MEP-MECH-PL, IFC 00-MEP-MECH-WS	
Item No.	Description	Manufacturer / Supplier	No. of Samples
1	Plumbing Valve	VALVE IT - M/s. Fluid Tech FZE LLC – U.A.E.	1 Nos
Note: Please return one signed off sample along with approval			

Main Contractor	M/s. TROJAN GENERAL CONTRACTING LLC
Name	CONFIDENTIAL
Signature	
Date	25-May-2019

ARCHGROUP Comments :

- Refer to Comments in the top sheet.

Accepted
03/6/19

STATUS of Approval :

Status A	Status B ✓	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator

TGC Manager

Resident Engineer/PM

ENGINEER'S REPRESENTATIVE/ AREA MANAGER :

Employer's Consent :

MEP :

Rove Hotels :

Project Director : Material Recommended ☐ / Rejected ☐



MATERIAL SUBMITTAL



Document Ref.: MS/TELAL/MBCC/VALVELT - 021

Rev : 00

Date : 19-November-2017

Project Name: TELAL HOTEL AND HOTEL APARTMENTS

Plot No.: C-003-024

Location: Tecom, Dubai

Employer: HE SHEIKH MOHAMMAD BIN ALI BIN RASHID AL NUAIMI

Contractor: M/s. Modern Building Contracting Co.

Manufacturer/Supplier :

VALVELT

From : Modern Building Contracting Co. LLC

To: M/S. GOLDEN SQUARE

SUBMITTAL TITLE : VALVELT - Technical Submittal for DRV and PRV Valves

DESCRIPTION : DRV AND PRV VALVES

Attachments: 2 Sets hard copy

SUBMITTED BY

RECEIVED BY

CONFIDENTIAL

M/S. GOLDEN SQUARE

Engineer's Comment's:

- as per the proposed valves for plumbing / water supply. Subject to the following:
- * Country of origin Certificate shall be provided upon material delivery.
 - * Draftsman's letter shall be submitted.

Signature: 23/11/2017

STATUS

☒ APPROVED

☐ APPROVED AS NOTED

☐ REVISE AND RESUBMIT

☐ REJECTED

ENGINEER APPROVED

MODERN BUILDING CONTRACTING CO. LLC

Telal Hotel

NAME

Signature

23 NOV 2017

Date

21/11/2017

DISTRIBUTION 11.7.17

Client


Q S

Planner

Site Engineer

File

RECEIVED



PROJECT Extension of Dubai Outlet Mall (DOM-II)
PLOT NO. 9117199
CLIENT Dubai Outlet Mall - Division of Al Ahli Holding Group
CONSULTANT Murabaa Architectural Design Consultancy
MAIN CONTRACTOR Gulf Spring Contracting
SUB-CONTRACTOR Trends Electro-Mechanical Works L.L.C

Material Submittal

Ref. No. TEMW-DOM II-MAT-AC-06

Rev. 0

Date: 24-Jun-18

Index:

Originator of the Submittal:

TRENDS ELECTRO MECHANICAL WORKS

Authorized Signature

Material Detail

Item Description	VALVES & STRAINERS
Location / Use	AS APPLICABLE
Specs. / BOQ / Drwg. Reference	SECTION 15100-VALVES
Material Specified	TOUR & ANDERSON / PEGLER / HATERSLAY / CRANE / WATTS / VALVEIT
Material Proposed	VALVEIT
Manufacturer / Local Supplier	VALVEIT / FLUID TECH FZE
Reason for Alternative	-
Remarks	-

List of Enclosure

(Tick the Related Box)

- ☒ Vendor's Technical Literature
- ☒ Compliance Statement
- ☒ Previous Test Results
- ☒ Copy of the Related Specs.
- ☒ List of Previous Projects Done
- ☒ Samples
- ☒ Others (Specify):

Main Contractor Statement: We certify that the material submitted herewith has been reviewed in details and in compliance with the contract drawings and specifications except as otherwise stated hereabove.

Main Contractor Signature:

Date:

Consultant Received:

Date:

consultant Resident Engineer's Comments:

* sizes as per Approved shop drawing
* installation shall follow manufacturer
recommendation

☐ A - Approved

☒ B - Approved As Noted

☐ C - Not Approved, Resubmit

☐ D - Incomplete, Resubmit

Consultant's Signature:

Date:

Client's Signature:

Date:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the contract requirement and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents.

RECEIVED 4 JUL 2018

DOM2/MS/A-001

RECEIVED
05 JUL 2018

BY: Kam time 11:00 AM
TRENDS

The Employer 	The Engineer 	The Contractor 	The MEP Contractor 
---	---	--	---

P100 -Cavalli Tower Al Sofouh Second, Dubai UAE (Plot No. 382-7585)

MATERIAL APPROVAL SUBMITTAL

Date: 17-Sep-24	Reference: P100-CSC-MAT-MEP-CHW-0018-R.0
Material Description: PN25 AUTOMATIC AIR VENT	
Model Number, Brand or Code of Proposed Material: VIT25ARDI - Valvet	☐ Refer to the Attached Summary of Proposed Materials
Location of Use:	
Specification Section: Section 15110 - VALVES	
Manufacturer Details	Supplier Details
Name: ValveIT	Name: FLUIDECH (FZE)
Country of origin: Italy	Country & City: Sharjah
Address:	Address: P.O. Box. 514454 Dubai, UAE
1. Compliance statement should be included in the submittal. 2. Copy of the Contract Specification Section should be included in the submittal 3. All sheets must be signed & sealed by the Contractor and the Specialist Subcontractor(s) 4. Submittal reference number should be noted on the attachments	

The Contractor Representative Signature



CONFIDENTIAL

Date: **17-Sep-2024**

THE ENGINEER COMMENTS:

** Refer to our comments on attached comments sheet.*

THE EMPLOYER COMMENTS:



ACTION: (As Marked)

☐ A - APPROVED

☒ B - APPROVED AS NOTED

☐ C - REVISE AND RESUBMIT

☐ D - FOR INFORMATION

Reviewed By:

For The Engineer:

For The Employer:
(When Applicable)

26/09/2024



الإستشاريون المتخصصون
شركة ذات مسؤولية محدودة
Allied Consultants Ltd

Transmittal Sheet

Date: 18 Sep 2024

Ref: DHE-ACD-AAC-TR-AR-013

Transmitted To

Transmitted By

CONFIDENTIAL	CONFIDENTIAL
Mechanical Engineer	Operations Manager
Al Ashram Contracting LLC	Allied Consultants Co. Dubai Branch

Package Transmitted For

Action ☒ Information ☐ Record ☐

Item	Item	Reference	Description	Notes	Status
1	DHE Plot 13.0008 Ellington House-1 Plot 6316928 Material Submittal for Double Eccentric Butterfly Valves along with Allied & EDC Comments	AAC-235-MAT-HVAC-053 R00	Soft Copy	Approved as Noted	B

Cc: Company Name Contact Name

Emaar District Cooling

Emaar Development

Allied Consultants

CONFIDENTIAL

Remarks

Allied Consultants Co. Dubai Branch

Al Ashram Contracting LLC

CONFIDENTIAL

Date: 18 Sep 2024

Printed Name over Signature

Date:



JUMEIRAH BEACH RESIDENCE (JBR)
DISTRICT COOLING PROJECT



EMPLOYER: EMPOWER ENERGY SOLUTIONS

MAIN CONTRACTOR : EMARAT ALOULA CONTRACTING ONE PERSON COMPANY L.L.C

ENGINEER: ALLIED CONSULTANTS LTD

PROJECT NO.: EMP-050-TR-379

SUBMITTAL COVER

TO:

ALLIED CONSULTANTS LTD.
P.O. Box No. 87816
Dubai, UAE.

FROM:

EMARAT ALOULA CONTRACTING ONE PERSON COMPANY L.L.C
P.O. Box No. 25693
Dubai, UAE

Submittal Ref.: 3129-EAC-EMP-MT-02-0008 Rev.01

DATE: 24-Jun-23

TYPE OF SUBMITTAL:

- ☐ SHOP DRAWING
☐ SAMPLES
☐ CATALOGUES AND PRODUCT DATA
☐ STRUCTURAL CALCULATIONS
☐ CERTIFICATE AND VERIFICATION PERFORMANCE

- ☐ PROGRAMME
☐ AS BUILT DRAWINGS
☐ O AND M MANUALS
☒ MATERIAL SUBMITTAL
☐ MOCK UPS

- ☐ METHOD STATEMENT
☐ SCHEDULES
☐ CD
☐ OTHERS

DISCIPLINE:

- ☐ CIVIL / STRUCTURAL
☐ ARCHITECTURAL

- ☐ BUILDING SERVICES
☐ ELECTRICAL

- ☐ CONTROL & MONITORING
☒ PROCESS ENGINEERING

Material Technical Approval (MTA) - Check valves of CHW & Make up Systems (M/s Gulf Circle LLC)

Contractor has reviewed the documents prior to submission:

Ahmed Hussien

SUBMITTAL REVIEW STATUS:

- ☐ A - APPROVED - Work may proceed
☒ B - APPROVED WITH COMMENTS - Work may proceed with review comments to be incorporated
☐ C - NOT APPROVED - Resubmission required before works may proceed
☐ D - REJECTED - Not accepted and not to be resubmitted
☐ E - For Information and Record

EMPLOYER COMMENTS:

ENGINEER COMMENTS:

1. Ensure all check valve to be non-slam spring loaded type as confirmed.
2. Warranty certificate and Type 3.1 certificate to be submitted along with material delivery as confirmed.

DISTRIBUTION STAMP		
003012900 - JBR DCP Upgradation Project		
Designation	Action	Info
PM		
Sr. PE (Civil)		
Sr. PE (M&P)		
Sr. PE (E&I)		
Planning		
QA		
Supervisor - Civil		
Supervisor - M&P		
Supervisor - E&I		
Site Engineer-Elect		
QA/QC - Mech		
QA/QC - Elec		
QA/QC - Civil		
HSE		
Surveying		
Store		
QC		
Technical		
Craftsman		
Others (Procurement)		
Date:	13-Jul-23	
PM Signature		

The checking and approval by the Engineer shall not relieve the Contractor of his obligation to perform the work in accordance with the contract documents and requirements of safety.

FOR AND BEHALF OF ALLIED CONSULTANTS

DATE RECEIVED:

24-Jun-2023



DATE RETURNED:

05-Jul-2023





JUMEIRAH BEACH RESIDENCE DISTRICT COOLING PLANT UPGRADATION PROJECT



Employer Ref No. EMP-050-TR-379

Material Technical Approval (MTA) Submittal

Document No. **3129-EAC-EMP-MT-02-0008** Rev. **0** Submission Date : **07-06-23**

General Information:

Material Description	Check valves of CHW & Make up Systems
Ifem Brand / Type / Model ref.	ValveIT
Projects specifications Ref.	TECH-SPEC-025
Purpose of the Material	Check valves of CHW & Make up Systems
BOQ Ref.	Bill No. 3, items B&C, Page 5 of 8

Source Information:

Manufacturer Name	M/s VaveIT			
Supplier Name (Skip if same manufacturer)	M/s Gulf Circle LLC			
Contacts details	Tel.	02 632 2344	Fax.	02 634 5284
	Address	Al Badie Tower, Level 3, Al Nasr St, Abu Dhabi, UAE	email	info@albadie.com

Attachments:

Material Approval Documents			Supplier Prequalification Documents		
1	Manufacturer Technical Catalogue	√	8	Company Profile	√
2	Compliance & Specifications Comparison sheet	√	9	Trade License	√
3	Picture of provided Sample & Country of origin	√	10	Company ISO Certificates	√
4	Material Inspection Certificate(s)	√	11	Projects list & Previous approvals	√
5	Material Technical & Safety Data Sheet(s)	√	12	Vendor List	X
6	Method Statement / Instructions	X	13	Others:	√
7	Copy of Draft Warranty	√			

Contractor Signatures

Originator: Sr. Project Engineer (PE) Signature: Name: CONFIDENTIAL Date: 07-Jun-23	Reviewed by: Quality Control (EAC-QC) Signature: Name: CONFIDENTIAL Date: 07-Jun-23	Reviewed by: Project Manager (PM) Signature: Name: CONFIDENTIAL Date: 07-Jun-23
--	--	--

Employer Rep. Approval

Check Code

<u>Reviewed / Approved by</u> Signature: _____ Name: _____ Date: _____	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="width: 20px; height: 20px;"></td><td style="width: 20px; height: 20px;">A</td></tr> <tr><td style="width: 20px; height: 20px;"></td><td style="width: 20px; height: 20px;">B</td></tr> <tr><td style="width: 20px; height: 20px;"></td><td style="width: 20px; height: 20px;">C</td></tr> <tr><td style="width: 20px; height: 20px;"></td><td style="width: 20px; height: 20px;">D</td></tr> <tr><td style="width: 20px; height: 20px;"></td><td style="width: 20px; height: 20px;">E</td></tr> </table>		A		B		C		D		E
	A										
	B										
	C										
	D										
	E										

Code- A	Approved	Code- B	Approved as Noted	Code- C	Revise and Resubmit	Code- D	Rejected	Code- E	For Information Only
---------	----------	---------	-------------------	---------	---------------------	---------	----------	---------	----------------------

Original : Project Document Controller Copy : Employer Rep.

PROJECT: Palms Residence Tower Project	EMPLOYER: شركة رؤية المستثمر Investor's Vision Company	N° EGDE-M-MAR019-R00												
CONTRACTOR: ego. designs	ENGINEER: CONSULTANT: erga GROUP Saudi branch	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">RECEIVED</td> <td style="width:30%;">Date: 21/12/2023</td> <td style="width:40%;">By: CBG</td> </tr> <tr> <td colspan="3">Ref: 3871-EGDE-MT-M-GS02-01</td> </tr> <tr> <td>Action By:</td> <td>Total</td> <td>Signature:</td> </tr> <tr> <td>DOT</td> <td>697546</td> <td></td> </tr> </table>	RECEIVED	Date: 21/12/2023	By: CBG	Ref: 3871-EGDE-MT-M-GS02-01			Action By:	Total	Signature:	DOT	697546	
RECEIVED	Date: 21/12/2023	By: CBG												
Ref: 3871-EGDE-MT-M-GS02-01														
Action By:	Total	Signature:												
DOT	697546													
MATERIAL APPROVAL REQUEST														

DISCIPLINE:				
Civil ☐	Architectural ☐	Electrical ☐	Mechanical ☒	Other ☐

LOCATION	ZONE	LOT	BLOCK	BLDG	FLOOR	AXES	DWG.
All areas					All Floors		

The material submitted for approval has been checked for conformity with drawings and specifications and any deviations noted herein:			
Material Description:	Valves for Plumbing Piping		
Type of Material:	Brass, Bronze...etc Materials		
Drawing Reference:	IFC drawings		
Specification Clause:	221119, 220523.12, 220523.13, 220523.14, 220523.15		
Fixing Location:	All Areas (Basement Floor, Tower)		
Technical Literature Attached	YES ☒	NO ☐	
Sample Attached	YES ☒	NO ☐	
Compliance Sheet Attached	YES ☒	NO ☐	
Manufacturer:	VALVEIT		
Country of Origin:	ITALY		
Local Agent:	Renewal Banner Trading Co.		
Type of Shipment	Land ☒	Sea ☐	Air ☐
Anticipated Period of delivery from placing order:	Partial Ex-Stock, Balance 10 – 14 Weeks		
Anticipated period when material to be used on site:	AS PER SCHEDULE		

Submitted By: Ehab Ahmed- MEP Manager	Date: 21.12.2023	Signature:
---------------------------------------	------------------	------------

COMMENTS:					
Approved; not to be used for fire applications.					
Global Status:	☐ A= Approved ☐ NAR=Not Approved, Resubmit	☒ AAN=Approved as Noted ☐ R=Rejected	☐ R&R=Revise, Re-Submit ☐ NFD=Need Further Detail	☐ CA=Conditional Approval ☐ NFI=Noted for info	
Reviewed By: DOT			Date: 21/12/2023		Signature:

Received By: CONFIDENTIAL	Date: _____	Signature:
---	-------------	------------

EGO DESIGNS
 23 DEC 2023
 THE PALMS

[Signature]
23/01/12

→ pressure drop, inlet & outlet size, etc. Installation instructions shall indicate the supports & optimum location from pump inlet.

- MIR to be submitted upon delivery along with COO certificate, Bill of Lading & all other relevant certificates (Packing list, etc.).



Tender No. 114-2023
Foul Drainage Network in Al Juraina and Al Juraina-1 Areas
Tender Documents (Package-1)

Volume 2 - Specifications

Volume 2C – SMDD Approved Vendor's List

AE362WTD-JAC-P1-GE-SPE-006 | 0


October 27, 2023

Government of Sharjah, Department of Public Works



حكومة الشارقة
دائرة الأشغال العامة

Government of Sharjah
Department of Public Works





SMDD - APPROVED VENDOR LIST

(700-902-Foul Sewage network in Al Juraina & Al Juraina 1 Areas)

September 2023

MECHANICAL

1	GATE VALVES/ BALL VALVES	
		CONFIDENTIAL
		VALVE IT
2	PENSTOCKS/ STOP LOGS	
		CONFIDENTIAL
3	NON-RETURN VALVES	
		CONFIDENTIAL
4	MECHANICAL CONTROL VALVES	CONFIDENTIAL
5	NEEDLE VALVES	CONFIDENTIAL
6	BUTTERFLY VALVES	
		CONFIDENTIAL



Tender No. 114-2023
Foul Drainage Network in Al Juraina and Al Juraina-1 Areas
Tender Documents (Package-2)

Volume 2 - Specifications

Volume 2C – SMDD Approved Vendor's List

AE362WTD-JAC-P2-GE-SPE-006 | 0

October 27, 2023

Government of Sharjah, Department of Public Works



حكومة الشارقة
دائرة الأشغال العامة

Government of Sharjah
Department of Public Works





SMDD - APPROVED VENDOR LIST

(700-902-Foul Sewage network in Al Juraina & Al Juraina 1 Areas)

September 2023

MECHANICAL

1	GATE VALVES/ BALL VALVES	
		CONFIDENTIAL
		VALVE IT
2	PENSTOCKS/ STOP LOGS	
		CONFIDENTIAL
3	NON-RETURN VALVES	
		CONFIDENTIAL
4	MECHANICAL CONTROL VALVES	CONFIDENTIAL
5	NEEDLE VALVES	
		CONFIDENTIAL
6	BUTTERFLY VALVES	
		CONFIDENTIAL

			Design & Build of The Pulse Beachfront Residence at Residential District of Dubai South	MATERIAL SUBMITTAL FORM	
Originator of Submittal			EMT ELECTROMECHANICAL WORKS	Dubai South Residential District Phase-6	Date
Reference No.			RD171-MAK-DXB-MAT-PLU-000037		
Rev. No.			0		
Date			11-Feb-24		
Item	Description	Discipline	List of Enclosure		
Specifications Reference	SECTION 15110	(Tick as Applicable)			
BOQ Reference	GENERAL	☐ Infrastructure	☐ Prequalification Documents		
Drawing Reference		☐ Architectural	☒ Trade License		
Material Specified	GATE VALVES	☐ Structural	☒ Vendor's Technical Literature		
Material Proposed	GATE VALVES	☐ Mechanical	☒ List of Previous Projects Done		
Manufacturer/Supplier	VALVEIT/ TPC FZE	☐ Electrical	☒ Compliance Statement Sheet (*)		
Address of Manufacturer	ITALY	☐ HVAC	☐ Method Statement		
Contractor Remarks	FOR VILLAS , RETAIL , CLUBHOUSE & SERVICE BLOCK	☒ Plumbing	☒ Previous Test Results		
Date Required on Site		☐ Finishes	☒ Copy of the Related Specifications		
Expected Date of Arrival of Material on Site		☐ External Works	☒ Sample with Sample Tag(**)		
Notes:	*Compliance statement sheet covering each paragraph and subparagraph of the specification and deviations should be clearly marked. Advantages/disadvantages between the specified and proposed to be mentioned. This statement must be attached to the relevant submittal form. **Samples should be presented on a sample board suitably identified with labels. Where it is not possible to present a sample on sample board due to size constraints, sample tag should be attached properly. Photos of samples should be included in the submittal. All document submissions should include one Original along with a soft copy in PDF format with this submission. When a resubmission is made based on The Engineer's comments, the compliance/Reply to each comment should be clearly mentioned point by point. The specified format should be filled in accordingly and attached to the submittal form.				
Contractor Statement	We certify that the material specified herewith has been reviewed in detail and is in compliance with the contract drawings and specifications except as otherwise stated above.				
Contractor's Authorized Representative Name	CONFIDENTIAL		Signature and Stamp		

ENGINEER'S COMMENTS	
Incoming Ref. No. , if applicable (to be filled by RE)	
-The quantity & sizes shall be as per the approved shop drawings and project requirement. -Country of origin certificates shall be provided along with the material delivery. -All required test certificates shall be provided along with the material delivery. -The proposed warranty shall be start from the project handing over date as per the project specification and requirement. -Subject to material inspection and installation approvals. -Subject to T&C and DEWA approvals. -This approval only for 50 mm or smaller gate valve.	
Continued on next page...	